

West Virginia Department of Environmental Protection
Division of Air Quality

Earl Ray Tomblin
Governor

Randy C. Huffman
Cabinet Secretary

Permit to Operate



Pursuant to
Title V
of the Clean Air Act

Issued to:
Longview Power, LLC
Longview Power Plant
R30-06100134-2013

John A. Benedict
Director

Expiration: *Issued:* *Draft/Proposed* • *Effective:* *[Equals issue date plus two weeks]*
[5 years after issuance date] • *Renewal Application Due:* *[6 months prior to expiration]*

Permit Number: **R30-06100134-2013**
Permittee: **Longview Power, LLC**
Facility Name: **Longview Power Plant**
Permittee Mailing Address: **966 Crafts Run Road, Maidsville, WV 26541**

This permit is issued in accordance with the West Virginia Air Pollution Control Act (West Virginia Code §§ 22-5-1 et seq.) and 45CSR30 — Requirements for Operating Permits. The permittee identified at the above-referenced facility is authorized to operate the stationary sources of air pollutants identified herein in accordance with all terms and conditions of this permit.

Facility Location:	Maidsville, Monongalia County, West Virginia
Facility Mailing Address:	Same as Above
Telephone Number:	(304) 599-0930 ext. 2204
Type of Business Entity:	LLC
Facility Description:	Longview is an electric generating unit with a 6,114 MMBtu/hr pulverized coal fired steam generator and a natural gas fired auxiliary boiler, with associated equipment including coal, limestone, and ash handling, cooling tower, an emergency generator, and a fire pump.
SIC Codes:	Primary 4911; Secondary NA; Tertiary NA
UTM Coordinates:	589.2 km Easting • 4395.7 km Northing • Zone 17

Permit Writer: Frederick Tipane

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.

Issuance of this Title V Operating Permit does not supersede or invalidate any existing permits under 45CSR13, 14 or 19, although all applicable requirements from such permits governing the facility's operation and compliance have been incorporated into the Title V Operating Permit.

Table of Contents

1.0	Emission Units and Active R13, R14, and R19 Permits.....	3
2.0	General Conditions.....	6
3.0	Facility-Wide Requirements.....	15

Source-specific Requirements

4.0	Coal Handling Equipment.....	25
5.0	PC Boiler And Cooling Tower	28
6.0	Auxiliary Boiler	43
7.0	Limestone and Ash Handling Systems	46
8.0	Internal Combustion Engines.....	50
APPENDIX A		54
APPENDIX B.....		59

1.0 Emission Units and Active R13, R14, and R19 Permits

1.1 Emission Units

Emission Unit ID	Emission Point ID	Emission Unit Description	Year Installed	Design Capacity	Control Device*
Coal Handling					
SL-C1	EC-3 or EC-6	Receiving Belt Conveyor	2007	1000 TPH	FE/DS
SL-C2	EC-4	Stacking Belt Conveyor	2007	1000 TPH	PE
SL-CS		Coal Stockpile	2007	120,000 Tons	MC
SL-C3	EC-7	Reclaim Belt Conveyor (Stockpile Reclaimer to Crusher House)	2007	700 TPH	FE/DS
SL-C4	EC-6	Emergency Belt Conveyor (Stockpile Reclaimer to Belt Conveyor L-C5)	2007	700 TPH	FE/DS
SL-C5	EC-12	Transfer Belt Conveyor (Transfer House to Crusher House) (By-passing the stockpile)	2007	1000 TPH	FE/DS
SL-SB		Crusher Surge Bin	2007	1400 TPH	FE/Crusher House (L-CH)
SL-CRA	EC-14,EC16	Crusher A	2007	700 TPH	
SL-CRB	EC-13, EC-15	Crusher B	2007	700 TPH	
SL-C6A	EC-19	Plant Feed Belt Conveyor A (Crusher A to Tripper Transfer)	2007	700 TPH	FE/DS
SL-C6B	EC-18	Plant Feed Belt Conveyor B(Crusher B to Tripper Transfer)	2007	700 TPH	FE/DS
SL-C7A & SL-TRA	EC-21A	Tripper Belt Conveyor A (L-C7A) w/traveling tripper A (L-TRA)	2007	700 TPH	FE/Tripper Transfer/Boiler Building
SL-C7B & SL-TRB	EC-21B	Tripper Belt Conveyor B (L-C7B) w/traveling tripper B (L-TRB)	2007	700 TPH	
SL-CS1	EC-21	Coal Silo No1	2007	1100 Tons	FE Boiler Building vented to DC (L-DC1)
SL-CS2	EC-21	Coal Silo No.2	2007	1100 Tons	
SL-CS3	EC-21	Coal Silo No. 3	2007	1100 Tons	
SL-CS4	EC-21	Coal Silo No. 4	2007	1100 Tons	
SL-CS5	EC-21	Coal Silo No. 5	2007	1100 Tons	
SL-CS6	EC-21	Coal Silo No. 6	2007	1100 Tons	
PC Boiler					
SB-1	EA-1	Pulverized Coal Fired Steam Generator (PC Boiler)	2007	6,114 MMBtu/hr	LNB/SCR (CB-3)/DSI (CB-4)/FF (CB-2)/WFGD (CB-1)

Emission Unit ID	Emission Point ID	Emission Unit Description	Year Installed	Design Capacity	Control Device*
ST-1	ET-1	Mechanical Draft Cooling Tower	2007	270,000 gpm	DE
Auxiliary Boiler					
SX-1	EX-1	Natural Gas Fired Boiler (Package Unit)	2007	225 MMBtu/hr	LNB
Limestone Handling					
SL-1	EL-1	Limestone Truck Hopper	2007	150 TPH	PE
SL-2	EL-2	Truck Feeder Belt Conveyor	2007	150 TPH	FE
SL-3 or SL-9	EL-3 or EL-9	Limestone Bucket Elevator	2007	150 TPH	FE
SL-4	EL-4	Limestone Storage Building Tripper Conveyor	2007	150 TPH	FE
SL-5		Limestone Storage Pile	2007	13,680 Tons	PE
SL-6	EL-6	Limestone Storage Building Reclaim Hopper	2007	150 TPH	FE
SL-10	EL-10	Limestone Bypass Belt Conveyor	2007	150 TPH	FE
SL-6/SL-11	EL-11	Reclaim Feeder Belt Conveyor	2007	150 TPH	FE/DC (CL-11)
SL-11	EL-11	Limestone Day Silo	2007	150 TPH	FE/DC (CL-11)
SL-12a SL-12b	EL-12a EL-12b	Limestone Feeder (A and B)	2007	82 TPH	FE
SL-13a SL-13b	EL-13a EL-13b	Ball Mill (A and B)	2007	82 TPH	FE
Ash Handling System					
SA-1a SA-1b	EA-1a EA-1b	Fly Ash Silos	2007	76 TPH	DC (CA-1)
SA-2a SA-2b	EA-2a EA-2b	Fly Ash Loadout	2007	76 TPH	PE
SA-3	EA-3	Bottom Ash Grinder	2007	22 TPH	N/A
SA-4	EA-4	Grinder or By-pass to conveyor	2007	22 TPH	N/A
SA-6	EA-6	Dry Flight Conveyor	2007	22 TPH	FE
SA-7		Bottom Ash Storage Pile	2007	1,170 Tons	FE
SA-8	EA-8	Hopper and Belt Feeder	2007	22 TPH	N/A
SA-12	EA-12	Belt Conveyor to Bottom Ash Silo	2007	22 TPH	N/A
SA-9	EA-9	Bottom Ash Silo	2007	200 TPH	N/A
SA-10	EA-10	Bottom Ash Loadout	2007	22 TPH	PE

Emission Unit ID	Emission Point ID	Emission Unit Description	Year Installed	Design Capacity	Control Device*
SA-11a SA-11b SA-11c	EA-11a EA-11b EA-11c	Blowers for the fly ash sweep system (SA-11b is a common spare)	2007	3,658 ACFM (ea.)	DC (Fabric Filters #1 & #2)
SG-1		Gypsum Storage Pile	2007	13,680 Tons	FE
Internal Combustion Engines					
SG-1	EG-1	Emergency Generator Engine	2007	4.1 MMBtu/hr (1528 hp)	N/A
SP-1	EP-1	Firewater Pump Engine	2007	2.1 MMBtu/hr (240 hp)	N/A

* Control Device Abbreviations: DC – Dust Collector, DS – Dust Suppression, FE - Full Enclosure, PE – Partial Enclosure, LNB – Low NO_x Burners, SCR – Selective Catalytic Reduction, DSI – Dry Sorbent Injection, FF - Fabric Filter, WFGD – Wet Flue Gas Desulphurization DE – Drift Eliminators, MC – Moisture Content

1.2. Active R13, R14, and R19 Permits

The underlying authority for any conditions from R13, R14, and/or R19 permits contained in this operating permit is cited using the original permit number (e.g. R13-1234). The current applicable version of such permit(s) is listed below.

Permit Number	Date of Issuance
R14-0024E	July 20, 2012

2.0 General Conditions

2.1 Definitions

- 2.1.1. All references to the "West Virginia Air Pollution Control Act" or the "Air Pollution Control Act" mean those provisions contained in W.Va. Code §§ 22-5-1 to 22-5-18.
- 2.1.2. The "Clean Air Act" means those provisions contained in 42 U.S.C. §§ 7401 to 7671q, and regulations promulgated thereunder.
- 2.1.3. "Secretary" means the Secretary of the Department of Environmental Protection or such other person to whom the Secretary has delegated authority or duties pursuant to W.Va. Code §§ 22-1-6 or 22-1-8 (45CSR§30-2.12.). The Director of the Division of Air Quality is the Secretary's designated representative for the purposes of this permit.
- 2.1.4. Unless otherwise specified in a permit condition or underlying rule or regulation, all references to a "rolling yearly total" shall mean the sum of the monthly data, values or parameters being measured, monitored, or recorded, at any given time for the previous twelve (12) consecutive calendar months.

2.2 Acronyms

CAAA	Clean Air Act Amendments	NSPS	New Source Performance
CBI	Confidential Business Information		Standards
CEM	Continuous Emission Monitor	PM	Particulate Matter
CES	Certified Emission Statement	PM₁₀	Particulate Matter less than 10µm in diameter
C.F.R. or CFR	Code of Federal Regulations		
CO	Carbon Monoxide	pph	Pounds per Hour
C.S.R. or CSR	Codes of State Rules	ppm	Parts per Million
DAQ	Division of Air Quality	PSD	Prevention of Significant Deterioration
DEP	Department of Environmental Protection	psi	Pounds per Square Inch
FOIA	Freedom of Information Act	SIC	Standard Industrial Classification
HAP	Hazardous Air Pollutant		
HON	Hazardous Organic NESHAP	SIP	State Implementation Plan
HP	Horsepower	SO₂	Sulfur Dioxide
lbs/hr or lb/hr	Pounds per Hour	TAP	Toxic Air Pollutant
LDAR	Leak Detection and Repair	TPY	Tons per Year
m	Thousand	TRS	Total Reduced Sulfur
MACT	Maximum Achievable Control Technology	TSP	Total Suspended Particulate
mm	Million	USEPA	United States Environmental Protection Agency
mmBtu/hr	Million British Thermal Units per Hour	UTM	Universal Transverse Mercator
mmft³/hr or mmcf/hr	Million Cubic Feet Burned per Hour	VEE	Visual Emissions Evaluation
NA or N/A	Not Applicable		
NAAQS	National Ambient Air Quality Standards	VOC	Volatile Organic Compounds
NESHAPS	National Emissions Standards for Hazardous Air Pollutants		
NO_x	Nitrogen Oxides		

2.3. Permit Expiration and Renewal

- 2.3.1. Permit duration. This permit is issued for a fixed term of five (5) years and shall expire on the date specified on the cover of this permit, except as provided in 45CSR§30-6.3.b. and 45CSR§30-6.3.c.
[45CSR§30-5.1.b.]
- 2.3.2. A permit renewal application is timely if it is submitted at least six (6) months prior to the date of permit expiration.
[45CSR§30-4.1.a.3.]
- 2.3.3. Permit expiration terminates the source's right to operate unless a timely and complete renewal application has been submitted consistent with 45CSR§30-6.2. and 45CSR§30-4.1.a.3.
[45CSR§30-6.3.b.]
- 2.3.4. If the Secretary fails to take final action to deny or approve a timely and complete permit application before the end of the term of the previous permit, the permit shall not expire until the renewal permit has been issued or denied, and any permit shield granted for the permit shall continue in effect during that time.
[45CSR§30-6.3.c.]

2.4. Permit Actions

- 2.4.1. This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.
[45CSR§30-5.1.f.3.]

2.5. Reopening for Cause

- 2.5.1. This permit shall be reopened and revised under any of the following circumstances:
 - a. Additional applicable requirements under the Clean Air Act or the Secretary's legislative rules become applicable to a major source with a remaining permit term of three (3) or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to 45CSR§§30-6.6.a.1.A. or B.
 - b. Additional requirements (including excess emissions requirements) become applicable to an affected source under Title IV of the Clean Air Act (Acid Deposition Control) or other legislative rules of the Secretary. Upon approval by U.S. EPA, excess emissions offset plans shall be incorporated into the permit.
 - c. The Secretary or U.S. EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

- d. The Secretary or U.S. EPA determines that the permit must be revised or revoked and reissued to assure compliance with the applicable requirements.

[45CSR§30-6.6.a.]

2.6. Administrative Permit Amendments

- 2.6.1. The permittee may request an administrative permit amendment as defined in and according to the procedures specified in 45CSR§30-6.4.

[45CSR§30-6.4.]

2.7. Minor Permit Modifications

- 2.7.1. The permittee may request a minor permit modification as defined in and according to the procedures specified in 45CSR§30-6.5.a.

[45CSR§30-6.5.a.]

2.8. Significant Permit Modification

- 2.8.1. The permittee may request a significant permit modification, in accordance with 45CSR§30-6.5.b., for permit modifications that do not qualify for minor permit modifications or as administrative amendments.

[45CSR§30-6.5.b.]

2.9. Emissions Trading

- 2.9.1. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in the permit and that are in accordance with all applicable requirements.

[45CSR§30-5.1.h.]

2.10. Off-Permit Changes

- 2.10.1. Except as provided below, a facility may make any change in its operations or emissions that is not addressed nor prohibited in its permit and which is not considered to be construction nor modification under any rule promulgated by the Secretary without obtaining an amendment or modification of its permit. Such changes shall be subject to the following requirements and restrictions:

- a. The change must meet all applicable requirements and may not violate any existing permit term or condition.
- b. The permittee must provide a written notice of the change to the Secretary and to U.S. EPA within two (2) business days following the date of the change. Such written notice shall describe each such change, including the date, any change in emissions, pollutants emitted, and any applicable requirement that would apply as a result of the change.
- c. The change shall not qualify for the permit shield.

- d. The permittee shall keep records describing all changes made at the source that result in emissions of regulated air pollutants, but not otherwise regulated under the permit, and the emissions resulting from those changes.
- e. No permittee may make any change subject to any requirement under Title IV of the Clean Air Act (Acid Deposition Control) pursuant to the provisions of 45CSR§30-5.9.
- f. No permittee may make any changes which would require preconstruction review under any provision of Title I of the Clean Air Act (including 45CSR14 and 45CSR19) pursuant to the provisions of 45CSR§30-5.9.

[45CSR§30-5.9.]

2.11. Operational Flexibility

- 2.11.1. The permittee may make changes within the facility as provided by § 502(b)(10) of the Clean Air Act. Such operational flexibility shall be provided in the permit in conformance with the permit application and applicable requirements. No such changes shall be a modification under any rule or any provision of Title I of the Clean Air Act (including 45CSR14 and 45CSR19) promulgated by the Secretary in accordance with Title I of the Clean Air Act and the change shall not result in a level of emissions exceeding the emissions allowable under the permit.

[45CSR§30-5.8]

- 2.11.2. Before making a change under 45CSR§30-5.8., the permittee shall provide advance written notice to the Secretary and to U.S. EPA, describing the change to be made, the date on which the change will occur, any changes in emissions, and any permit terms and conditions that are affected. The permittee shall thereafter maintain a copy of the notice with the permit, and the Secretary shall place a copy with the permit in the public file. The written notice shall be provided to the Secretary and U.S. EPA at least seven (7) days prior to the date that the change is to be made, except that this period may be shortened or eliminated as necessary for a change that must be implemented more quickly to address unanticipated conditions posing a significant health, safety, or environmental hazard. If less than seven (7) days notice is provided because of a need to respond more quickly to such unanticipated conditions, the permittee shall provide notice to the Secretary and U.S. EPA as soon as possible after learning of the need to make the change.

[45CSR§30-5.8.a.]

- 2.11.3. The permit shield shall not apply to changes made under 45CSR§30-5.8., except those provided for in 45CSR§30-5.8.d. However, the protection of the permit shield will continue to apply to operations and emissions that are not affected by the change, provided that the permittee complies with the terms and conditions of the permit applicable to such operations and emissions. The permit shield may be reinstated for emissions and operations affected by the change:

- a. If subsequent changes cause the facility's operations and emissions to revert to those authorized in the permit and the permittee resumes compliance with the terms and conditions of the permit, or
- b. If the permittee obtains final approval of a significant modification to the permit to incorporate the change in the permit.

[45CSR§30-5.8.c.]

- 2.11.4. "Section 502(b)(10) changes" are changes that contravene an express permit term. Such changes do not include changes that would violate applicable requirements or contravene enforceable permit terms and conditions that are monitoring (including test methods), recordkeeping, reporting, or compliance certification requirements.

[45CSR§30-2.39]

2.12. Reasonably Anticipated Operating Scenarios

- 2.12.1. The following are terms and conditions for reasonably anticipated operating scenarios identified in this permit.
- a. Contemporaneously with making a change from one operating scenario to another, the permittee shall record in a log at the permitted facility a record of the scenario under which it is operating and to document the change in reports submitted pursuant to the terms of this permit and 45CSR30.
 - b. The permit shield shall extend to all terms and conditions under each such operating scenario; and
 - c. The terms and conditions of each such alternative scenario shall meet all applicable requirements and the requirements of 45CSR30.

[45CSR§30-5.1.i.]

2.13. Duty to Comply

- 2.13.1. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the West Virginia Code and the Clean Air Act and is grounds for enforcement action by the Secretary or USEPA; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

[45CSR§30-5.1.f.1.]

2.14. Inspection and Entry

- 2.14.1. The permittee shall allow any authorized representative of the Secretary, upon the presentation of credentials and other documents as may be required by law, to perform the following:
- a. At all reasonable times (including all times in which the facility is in operation) enter upon the permittee's premises where a source is located or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
 - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
 - c. Inspect at reasonable times (including all times in which the facility is in operation) any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit;

- d. Sample or monitor at reasonable times substances or parameters to determine compliance with the permit or applicable requirements or ascertain the amounts and types of air pollutants discharged.

[45CSR§30-5.3.b.]

2.15. Schedule of Compliance

- 2.15.1. For sources subject to a compliance schedule, certified progress reports shall be submitted consistent with the applicable schedule of compliance set forth in this permit and 45CSR§30-4.3.h., but at least every six (6) months, and no greater than once a month, and shall include the following:
 - a. Dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
 - b. An explanation of why any dates in the schedule of compliance were not or will not be met, and any preventative or corrective measure adopted.

[45CSR§30-5.3.d.]

2.16. Need to Halt or Reduce Activity not a Defense

- 2.16.1. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. However, nothing in this paragraph shall be construed as precluding consideration of a need to halt or reduce activity as a mitigating factor in determining penalties for noncompliance if the health, safety, or environmental impacts of halting or reducing operations would be more serious than the impacts of continued operations.

[45CSR§30-5.1.f.2.]

2.17. Emergency

- 2.17.1. An "emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

[45CSR§30-5.7.a.]

- 2.17.2. Effect of any emergency. An emergency constitutes an affirmative defense to an action brought for noncompliance with such technology-based emission limitations if the conditions of 45CSR§30-5.7.c. are met.

[45CSR§30-5.7.b.]

- 2.17.3. The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;

- b. The permitted facility was at the time being properly operated;
- c. During the period of the emergency the permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- d. Subject to the requirements of 45CSR§30-5.1.c.3.C.1, the permittee submitted notice of the emergency to the Secretary within one (1) working day of the time when emission limitations were exceeded due to the emergency and made a request for variance, and as applicable rules provide. This notice, report, and variance request fulfills the requirement of 45CSR§30-5.1.c.3.B. This notice must contain a detailed description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

[45CSR§30-5.7.c.]

- 2.17.4. In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof.

[45CSR§30-5.7.d.]

- 2.17.5. This provision is in addition to any emergency or upset provision contained in any applicable requirement.

[45CSR§30-5.7.e.]

2.18. Federally-Enforceable Requirements

- 2.18.1. All terms and conditions in this permit, including any provisions designed to limit a source's potential to emit and excepting those provisions that are specifically designated in the permit as "State-enforceable only", are enforceable by the Secretary, USEPA, and citizens under the Clean Air Act.

[45CSR§30-5.2.a.]

- 2.18.2. Those provisions specifically designated in the permit as "State-enforceable only" shall become "Federally-enforceable" requirements upon SIP approval by the USEPA.

2.19. Duty to Provide Information

- 2.19.1. The permittee shall furnish to the Secretary within a reasonable time any information the Secretary may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Secretary copies of records required to be kept by the permittee. For information claimed to be confidential, the permittee shall furnish such records to the Secretary along with a claim of confidentiality in accordance with 45CSR31. If confidential information is to be sent to USEPA, the permittee shall directly provide such information to USEPA along with a claim of confidentiality in accordance with 40 C.F.R. Part 2.

[45CSR§30-5.1.f.5.]

2.20. Duty to Supplement and Correct Information

- 2.20.1. Upon becoming aware of a failure to submit any relevant facts or a submittal of incorrect information in any permit application, the permittee shall promptly submit to the Secretary such supplemental facts or corrected information.

[45CSR§30-4.2.]

2.21. Permit Shield

2.21.1. Compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance provided that such applicable requirements are included and are specifically identified in this permit or the Secretary has determined that other requirements specifically identified are not applicable to the source and this permit includes such a determination or a concise summary thereof.

[45CSR§30-5.6.a.]

2.21.2. Nothing in this permit shall alter or affect the following:

- a. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance; or
- b. The applicable requirements of the Code of West Virginia and Title IV of the Clean Air Act (Acid Deposition Control), consistent with § 408 (a) of the Clean Air Act.
- c. The authority of the Administrator of U.S. EPA to require information under § 114 of the Clean Air Act or to issue emergency orders under § 303 of the Clean Air Act.

[45CSR§30-5.6.c.]

2.22. Credible Evidence

2.22.1. Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee including but not limited to any challenge to the credible evidence rule in the context of any future proceeding.

[45CSR§30-5.3.e.3.B. and 45CSR38]

2.23. Severability

2.23.1. The provisions of this permit are severable. If any provision of this permit, or the application of any provision of this permit to any circumstance is held invalid by a court of competent jurisdiction, the remaining permit terms and conditions or their application to other circumstances shall remain in full force and effect.

[45CSR§30-5.1.e.]

2.24. Property Rights

2.24.1. This permit does not convey any property rights of any sort or any exclusive privilege.

[45CSR§30-5.1.f.4]

2.25. Acid Deposition Control

2.25.1. Emissions shall not exceed any allowances that the source lawfully holds under Title IV of the Clean Air Act (Acid Deposition Control) or rules of the Secretary promulgated thereunder.

- a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the acid deposition control program, provided that such increases do not require a permit revision under any other applicable requirement.
- b. No limit shall be placed on the number of allowances held by the source. The source may not, however, use allowances as a defense to noncompliance with any other applicable requirement.
- c. Any such allowance shall be accounted for according to the procedures established in rules promulgated under Title IV of the Clean Air Act.

[45CSR§30-5.1.d.]

- 2.25.2. Where applicable requirements of the Clean Air Act are more stringent than any applicable requirement of regulations promulgated under Title IV of the Clean Air Act (Acid Deposition Control), both provisions shall be incorporated into the permit and shall be enforceable by the Secretary and U. S. EPA.

[45CSR§30-5.1.a.2.]

3.0 Facility-Wide Requirements

3.1. Limitations and Standards

- 3.1.1. **Open burning.** The open burning of refuse by any person is prohibited except as noted in 45CSR§6-3.1.
[45CSR§6-3.1.]
- 3.1.2. **Open burning exemptions.** The exemptions listed in 45CSR§6-3.1 are subject to the following stipulation: Upon notification by the Secretary, no person shall cause or allow any form of open burning during existing or predicted periods of atmospheric stagnation. Notification shall be made by such means as the Secretary may deem necessary and feasible.
[45CSR§6-3.2.]
- 3.1.3. **Asbestos.** The permittee is responsible for thoroughly inspecting the facility, or part of the facility, prior to commencement of demolition or renovation for the presence of asbestos and complying with 40 C.F.R. § 61.145, 40 C.F.R. § 61.148, and 40 C.F.R. § 61.150. The permittee, owner, or operator must notify the Secretary at least ten (10) working days prior to the commencement of any asbestos removal on the forms prescribed by the Secretary if the permittee is subject to the notification requirements of 40 C.F.R. § 61.145(b)(3)(i). The USEPA, the Division of Waste Management and the Bureau for Public Health - Environmental Health require a copy of this notice to be sent to them.
[40 C.F.R. §61.145(b) and 45CSR34]
- 3.1.4. **Odor.** No person shall cause, suffer, allow or permit the discharge of air pollutants which cause or contribute to an objectionable odor at any location occupied by the public.
[45CSR§4-3.1 State-Enforceable only.]
- 3.1.5. **Standby plan for reducing emissions.** When requested by the Secretary, the permittee shall prepare standby plans for reducing the emissions of air pollutants in accordance with the objectives set forth in Tables I, II, and III of 45CSR11.
[45CSR§11-5.2]
- 3.1.6. **Emission inventory.** The permittee is responsible for submitting, on an annual basis, an emission inventory in accordance with the submittal requirements of the Division of Air Quality.
[W.Va. Code § 22-5-4(a)(14); 45CSR14, R14-0024 §3.5.5.]
- 3.1.7. **Ozone-depleting substances.** For those facilities performing maintenance, service, repair or disposal of appliances, the permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 C.F.R. Part 82, Subpart F, except as provided for Motor Vehicle Air Conditioners (MVACs) in Subpart B:
- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the prohibitions and required practices pursuant to 40 C.F.R. §§ 82.154 and 82.156.
 - b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 C.F.R. § 82.158.

- c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 C.F.R. § 82.161.

[40 C.F.R. 82, Subpart F]

- 3.1.8. **Risk Management Plan.** Should this stationary source, as defined in 40 C.F.R. § 68.3, become subject to Part 68, then the owner or operator shall submit a risk management plan (RMP) by the date specified in 40 C.F.R. § 68.10 and shall certify compliance with the requirements of Part 68 as part of the annual compliance certification as required by 40 C.F.R. Part 70 or 71.

[40 C.F.R. 68]

- 3.1.9. **CAIR NO_x Annual Trading Program.** The permittee shall comply with the standard requirements set forth in the attached CAIR Permit Application (see Appendix A) and the CAIR permit requirements set forth in 45CSR39 for each CAIR NO_x Annual source. The complete CAIR Permit Application shall be the CAIR Permit portion of the Title V permit administered in accordance with 45CSR30.

[45CSR§§39-6.1.b. and 20.1.]

- a. The CAIR Permit portion of this permit is deemed to incorporate automatically the definitions of terms under 45CSR§39-2 and, upon recordation by the Administrator under sections 51 through 57, or 60 through 62 of 45CSR39, every allocation, transfer, or deduction of a CAIR NO_x Annual allowance to or from the compliance account of the CAIR NO_x Annual source covered by the permit.

[45CSR§39-23.2.]

- b. Except as provided in 45CSR§39-23.2, the Secretary will revise the CAIR Permit portion of this permit, as necessary, in accordance with the operating permit revision requirements set forth in 45CSR30.

[45CSR§39-24.1.]

- 3.1.10. **CAIR NO_x Ozone Season Trading Program.** The permittee shall comply with the standard requirements set forth in the attached CAIR Permit Application (see Appendix A) and the CAIR permit requirements set forth in 45CSR40 for each CAIR NO_x Ozone Season source. The complete CAIR Permit Application shall be the CAIR Permit portion of the Title V permit administered in accordance with 45CSR30.

[45CSR§§40-6.1.b. and 20.1.]

- a. The CAIR Permit portion of this permit is deemed to incorporate automatically the definitions of terms under 45CSR§40-2 and, upon recordation by the Administrator under sections 51 through 57, or 60 through 62 of 45CSR40, every allocation, transfer, or deduction of a CAIR NO_x Ozone Season allowance to or from the compliance account of the CAIR NO_x Ozone Season source covered by the permit.

[45CSR§40-23.2.]

- b. Except as provided in 45CSR§40-23.2, the Secretary will revise the CAIR Permit portion of this permit, as necessary, in accordance with the operating permit revision requirements set forth in 45CSR30.

[45CSR§40-24.1.]

- 3.1.11. **CAIR SO₂ Trading Program.** The permittee shall comply with the standard requirements set forth in the attached CAIR Permit Application (see Appendix A) and the CAIR permit requirements set forth in 45CSR41 for each CAIR SO₂ source. The complete CAIR Permit Application shall be the CAIR Permit portion of the Title V permit administered in accordance with 45CSR30.

[45CSR§§41-6.1.b. and 20.1.]

- a. The CAIR Permit portion of this permit is deemed to incorporate automatically the definitions of terms under 45CSR§41-2 and, upon recordation by the Administrator under sections 51 through 57, or 60 through 62 of 45CSR41, every allocation, transfer, or deduction of a CAIR SO₂ allowance to or from the compliance account of the CAIR SO₂ source covered by the permit.

[45CSR§41-23.2.]

- b. Except as provided in 45CSR§41-23.2, the Secretary will revise the CAIR Permit portion of this permit, as necessary, in accordance with the operating permit revision requirements set forth in 45CSR30.

[45CSR§41-24.1.]

- 3.1.12. For the purposes of mitigating acid deposition and visibility impacts into the Dolly Sods Wilderness Area, James River Face Wilderness Area, Otter Creek Wilderness Area, and Shenandoah National Park, (collectively the Class I Areas), the permittee shall obtain and permanently retire sulfur dioxide allowances in accordance with the following.

- a. The required number of sulfur dioxide allowances for the respective calendar year shall be determined by the actual sulfur dioxide emission, in tons, emitted from the PC boiler during each calendar year plus 10% and multiplied by the corresponding offset ratio as defined in paragraph b of this condition.
- b. Acceptable sulfur dioxide allowances under this condition shall be from facilities that were allocated sulfur dioxide allowances under 40 CFR 73 and that are located within one of the five quadrants as defined in the following table:

Quadrant	Northeast	Northwest	Southeast	Southwest	Western Area
Offset Ratio	1:4	1:1	1:4	1:1	1:1
	Longitude/ Latitude	Longitude/ Latitude	Longitude/ Latitude	Longitude/ Latitude	Longitude/Latitude
Northeast Corner	-77.528845/ 40.100689	-79.312228/ 40.119496	-77.73267/ 38.570665	-79.338651/ 38.603830	-80.555/39.0836
Northwest Corner	-79.312228/ 40.119496	-80.555022/ 40.151887	-79.338651/ 38.603830	-80.944637/ 38.628678	-82.1306/39.0836
Southeast Corner	-77.73267/ 38.570665	-79.338651/ 38.603830	-77.671583/ 37.077938	-79.393612/ 37.088164	-80.555/38.1983
Southwest Corner	-79.338651/ 38.603830	-80.944637/ 38.628678	-79.393612/ 37.088164	-80.573361/ 37.123911	-82.1306/38.1983

- c. The vintage year of the allowances shall correspond to the calendar year that is being mitigated.
- d. The permittee shall transfer these allowances into an account in the Allowance Tracking System administered by with U.S. EPA for the Acid Rain Program, to be identified by the Director. These retired allowances can never be used to meet any compliance requirement under the Clean Air Act or any State Implementation Plan.
- e. The permittee shall submit a report to the Director no later than 60 days after the end of each calendar year, which shall contain the amount of sulfur dioxide emitted; the amount, facility, location of facility,

vintage year of allowances retired, proof that allowances have been transferred into account identified by the Director and any applicable serial or other identification associated with the retired allowances.

- f. At any time, but after at least 30 days notice to the public and the Federal Land Managers the Director may approve an alternative mitigation plan in lieu of this condition. At a minimum, such a plan shall result in actual sulfur dioxide reductions from an existing stationary source(s) within one of the four quadrants as defined in b of this condition of at least 2,142 tons per year multiplied by the corresponding offset ratio. Such reductions must be practically enforceable, permanent, and quantifiable, and must be created after March 2, 2004. The reductions must result in the same or greater reduction in acid deposition and visibility impacts to the Class I Areas as the purchase of allowances as set forth in Paragraphs 3.1.12.a through 3.1.12.e herein.

[45CSR14, R14-0024 §3.1.7. State-Enforceable only]

- 3.1.13. Notwithstanding the specific emission limits of Hazardous Air Pollutants (HAPs) in this permit the facility wide total emissions to the atmosphere of HAPs as defined by Section 112(b) of the 1990 Clean Air Act Amendments shall be less than 10 TPY of any single HAP and less than 25 TPY of combined total of HAPs from the facility.
 - a. The permittee shall on a monthly basis determine and keep records of the total amount of HAPs emitted from the facility during the past year on a rolling 12-month total basis. Records of this determination shall be on an individual HAP basis and summing the total amount of HAP emitted during the previous 12-months. All records used to determine the amount of HAPs emitted must include but not be limited to sample calculations and collected data (i.e. fuel consumption, hours operated).

[45CSR§§13-15.b. and 5.5.; R14-0024 §3.1.8.]

- 3.1.14. Fugitive dust control measures as proposed in Permit Applications R14-0024 shall be installed, maintained, and operated in such a manner as to minimize dust generation and atmospheric entrainment pursuant to Section 5 of 45 CSR 2. Such measures shall include, but not be limited to, the following:
 - a. Water spray systems for the purpose of fugitive particulate dust control shall be designed, installed, operated, and maintained to minimize the generation of fugitive particulate emissions from the wind erosion of stockpiles.

A properly designed, installed, and maintained winterization system on each of the water spray systems shall be in place to functionally maintain all fugitive particulate dust control during periods when ambient temperature falls to or below 32 degrees Fahrenheit.
 - b. The permittee shall maintain a fixed water spray system and/or a water truck on site at the facility and in good operating condition, and shall utilize same to apply water, or a mixture of water and an environmentally acceptable dust control additive, hereinafter referred to as solution, as often as necessary to minimize the atmospheric entrainment of fugitive particulate emissions that may be generated from haul roads and other work areas where mobile equipment is used.

The spray bar shall be equipped with commercially available spray nozzles, of sufficient size and number, so as to provide adequate coverage to the surface being treated.

The pump delivering the water or solution shall be of sufficient size and capacity to be capable of delivering to the spray nozzle(s) an adequate quantity of water, or solution, and at a sufficient pressure.

- c. The permittee shall maintain and operate as needed to minimize fugitive particulate matter from haul roads a street sweeper or other mobile equipment designed to remove debris (road dust) from paved plant roads. This activity shall be conducted daily to minimize fugitive particulate matter from paved plant roadways.
- d. All belt conveyors shall be at a minimum partially enclosed.

[45CSR14, R14-0024 §3.1.9.; 45CSR§2-5]

- 3.1.15. All roadways at the permitted facility shall be paved, and maintained in such a way to minimize fugitive particulate matter emissions.

[45CSR14, R14-0024 §3.1.10.]

- 3.1.16. The permittee shall construct and maintain an industrial fence around this permitted facility as defined in the March 3, 2003 submittal of the Air Quality Modeling Analysis Report. This industrial fence shall be constructed in such a manner to reasonably prevent the public from accessing this permitted facility.

[45CSR14, R14-0024 §3.1.11.]

3.2. Monitoring Requirements

- 3.2.1. Visible emission checks as required in this permit (conditions 4.2.1. & 7.2.1.), shall be conducted in accordance with the following:

The visible emission check shall determine the presence or absence of visible emissions. At a minimum, the observer must be trained and knowledgeable regarding the effects of background contrast, ambient lighting, observer position relative to lighting, wind, and the presence of uncombined water (condensing water vapor) on the visibility of emissions. This training may be obtained from written materials found in the References 1 and 2 from 40CFR Part 60, Appendix A, Method 22 or from the lecture portion of the 40CFR Part 60, Appendix A, Method 9 certification course.

Visible emission checks shall be conducted at least once per calendar month with a maximum of forty-five (45) days between consecutive readings. These checks shall be performed at each source (stack, transfer point, fugitive emission source, etc.) for a sufficient time interval, but no less than one (1) minute, to determine if any visible emissions are present. Visible emission checks shall be performed during periods of facility operation and appropriate weather conditions.

If visible emissions are present at a source(s) for three (3) consecutive monthly checks, the permittee shall conduct an opacity reading at that source(s) using the procedures and requirements of Method 9 and any other applicable procedure as outlined in **Testing Requirements Subsection** for that particular emission source in this permit as soon as practicable, but within seventy-two (72) hours of the final visual emission check. A Method 9 observation at a source(s) restarts the count of the number of consecutive readings with the presence of visible emissions.

Records of the checks shall be maintained in accordance with conditions 3.4.1. and 3.4.2.

[45CSR§30-5.1.c.]

3.3. Testing Requirements

- 3.3.1. **Stack testing.** As per provisions set forth in this permit or as otherwise required by the Secretary, in accordance with the West Virginia Code, underlying regulations, permits and orders, the permittee shall conduct test(s) to determine compliance with the emission limitations set forth in this permit and/or established or set forth in underlying documents. The Secretary, or his duly authorized representative, may at his option witness or conduct such test(s). Should the Secretary exercise his option to conduct such test(s), the operator shall provide all necessary sampling connections and sampling ports to be located in such manner as the Secretary may require, power for test equipment and the required safety equipment, such as scaffolding, railings and ladders, to comply with generally accepted good safety practices. Such tests shall be conducted in accordance with the methods and procedures set forth in this permit or as otherwise approved or specified by the Secretary in accordance with the following:
- a. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with 40 C.F.R. Parts 60, 61, and 63, if applicable, in accordance with the Secretary's delegated authority and any established equivalency determination methods which are applicable.
 - b. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with applicable requirements which do not involve federal delegation. In specifying or approving such alternative testing to the test methods, the Secretary, to the extent possible, shall utilize the same equivalency criteria as would be used in approving such changes under Section 3.3.1.a. of this permit.
 - c. All periodic tests to determine mass emission limits from or air pollutant concentrations in discharge stacks and such other tests as specified in this permit shall be conducted in accordance with an approved test protocol. Unless previously approved, such protocols shall be submitted to the Secretary in writing at least thirty (30) days prior to any testing and shall contain the information set forth by the Secretary. In addition, the permittee shall notify the Secretary at least fifteen (15) days prior to any testing so the Secretary may have the opportunity to observe such tests. This notification shall include the actual date and time during which the test will be conducted and, if appropriate, verification that the tests will fully conform to a referenced protocol previously approved by the Secretary.
 - d. The permittee shall submit a report of the results of the stack test within 60 days of completion of the test. The test report shall provide the information necessary to document the objectives of the test and to determine whether proper procedures were used to accomplish these objectives. The report shall include the following: the certification described in paragraph 3.5.1; a statement of compliance status, also signed by a responsible official; and, a summary of conditions which form the basis for the compliance status evaluation. The summary of conditions shall include the following:
 1. The permit or rule evaluated, with the citation number and language.
 2. The result of the test for each permit or rule condition.
 3. A statement of compliance or non-compliance with each permit or rule condition.

[WV Code §§ 22-5-4(a)(14-15) and 45CSR14]

3.4. Recordkeeping Requirements

- 3.4.1. **Retention of records.** The permittee shall retain records of all required monitoring data and support information for a period of at least five (5) years from the date of monitoring sample, measurement, report, application, or record creation date. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Where appropriate, records may be maintained in computerized form in lieu of the above records.

[45CSR§30-5.1.c.2.B.; 45CSR14, R14-0024 §3.4.1.]

- 3.4.2. **Monitoring information.** The permittee shall keep records of monitoring information that include the following:

- a. The date, place as defined in this permit and time of sampling or measurements;
- b. The date(s) analyses were performed;
- c. The company or entity that performed the analyses;
- d. The analytical techniques or methods used;
- e. The results of the analyses; and
- f. The operating conditions existing at the time of sampling or measurement.

[45CSR§30-5.1.c.2.A.]

- 3.4.3. **Odors.** For the purposes of 45CSR4, the permittee shall maintain a record of all odor complaints received, any investigation performed in response to such a complaint, and any responsive action(s) taken.

[45CSR§30-5.1.c. State-Enforceable only.]

3.5. Reporting Requirements

- 3.5.1. **Responsible official.** Any application form, report, or compliance certification required by this permit to be submitted to the DAQ and/or USEPA shall contain a certification by the responsible official that states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

[45CSR§§30-4.4. and 5.1.c.3.D.]

- 3.5.2. A permittee may request confidential treatment for the submission of reporting required under 45CSR§30-5.1.c.3. pursuant to the limitations and procedures of W.Va. Code § 22-5-10 and 45CSR31.

[45CSR§30-5.1.c.3.E.]

- 3.5.3. Except for the electronic submittal of the annual certification to the USEPA as required in 3.5.5 below, all notices, requests, demands, submissions and other communications required or permitted to be made to the Secretary of DEP and/or USEPA shall be made in writing and shall be deemed to have been duly given when delivered by hand, mailed first class or by private carrier with postage prepaid to the address(es) set

forth below or to such other person or address as the Secretary of the Department of Environmental Protection may designate:

If to the DAQ:

Director
WVDEP
Division of Air Quality
601 57th Street SE
Charleston, WV 25304

Phone: 304/926-0475
FAX: 304/926-0478

If to the US EPA:

Associate Director
Office of Air Enforcement and Compliance
Assistance (3AP20)
U. S. Environmental Protection Agency
Region III
1650 Arch Street
Philadelphia, PA 19103-2029

- 3.5.4. **Certified emissions statement.** The permittee shall submit a certified emissions statement and pay fees on an annual basis in accordance with the submittal requirements of the Division of Air Quality.
[45CSR§30-8.]
- 3.5.5. **Compliance certification.** The permittee shall certify compliance with the conditions of this permit on the forms provided by the DAQ. In addition to the annual compliance certification, the permittee may be required to submit certifications more frequently under an applicable requirement of this permit. The annual certification shall be submitted to the DAQ and USEPA on or before March 15 of each year, and shall certify compliance for the period ending December 31. The annual certification to the USEPA shall be submitted in electronic format only. It shall be submitted by e-mail to the following address: R3_APD_Permits@epa.gov. The permittee shall maintain a copy of the certification on site for five (5) years from submittal of the certification.
[45CSR§30-5.3.e.]
- 3.5.6. **Semi-annual monitoring reports.** The permittee shall submit reports of any required monitoring on or before September 15 for the reporting period January 1 to June 30 and on or before March 15 for the reporting period July 1 to December 31. All instances of deviation from permit requirements must be clearly identified in such reports. All required reports must be certified by a responsible official consistent with 45CSR§30-4.4.
[45CSR§30-5.1.c.3.A.]
- 3.5.7. **Emergencies.** For reporting emergency situations, refer to Section 2.17 of this permit.
- 3.5.8. **Deviations.**
- a. In addition to monitoring reports required by this permit, the permittee shall promptly submit supplemental reports and notices in accordance with the following:
 1. Any deviation resulting from an emergency or upset condition, as defined in 45CSR§30-5.7., shall be reported by telephone or telefax within one (1) working day of the date on which the permittee becomes aware of the deviation, if the permittee desires to assert the affirmative defense in accordance with 45CSR§30-5.7. A written report of such deviation, which shall include the

probable cause of such deviations, and any corrective actions or preventative measures taken, shall be submitted and certified by a responsible official within ten (10) days of the deviation.

2. Any deviation that poses an imminent and substantial danger to public health, safety, or the environment shall be reported to the Secretary immediately by telephone or telefax. A written report of such deviation, which shall include the probable cause of such deviation, and any corrective actions or preventative measures taken, shall be submitted by the responsible official within ten (10) days of the deviation.
3. Deviations for which more frequent reporting is required under this permit shall be reported on the more frequent basis.
4. All reports of deviations shall identify the probable cause of the deviation and any corrective actions or preventative measures taken.

[45CSR§30-5.1.c.3.C.]

- b. The permittee shall, in the reporting of deviations from permit requirements, including those attributable to upset conditions as defined in this permit, report the probable cause of such deviations and any corrective actions or preventive measures taken in accordance with any rules of the Secretary.

[45CSR§30-5.1.c.3.B.]

- 3.5.9. **New applicable requirements.** If any applicable requirement is promulgated during the term of this permit, the permittee will meet such requirements on a timely basis, or in accordance with a more detailed schedule if required by the applicable requirement.

[45CSR§30-4.3.h.1.B.]

3.6. Compliance Plan

- 3.6.1. NA

3.7. Permit Shield

- 3.7.1. The permittee is hereby granted a permit shield in accordance with 45CSR§30-5.6. The permit shield applies provided the permittee operates in accordance with the information contained within this permit.
- 3.7.2. The following requirements specifically identified are not applicable to the source based on the determinations set forth below. The permit shield shall apply to the following requirements provided the conditions of the determinations are met.

45CSR5	Pursuant to 45CSR5, if 45CSR2 is applicable to the facility, then the facility is exempt from 45CSR5. 45CSR2 is applicable to the facility.
--------	---

45CSR17	Pursuant to 45CSR17, if 45CSR2 is applicable to the facility, then the facility is exempt from 45CSR17. 45CSR2 is applicable to the facility.
---------	---

40 C.F.R. 60
Subpart Kb

The facility does not include storage vessels greater than or equal to 75 cubic meters that are used to store volatile organic liquids for which construction, reconstruction or modification commenced after July 23, 1984.

40 CFR 63
Subpart JJJJJ

The auxiliary boiler is a gas-fired boiler and therefore not subject to this subpart pursuant to §63.11195(e).

4.0 Coal Handling Equipment [emission point ID(s): EC-3, 4, 6, 7, 12-16, 18, 19, 21A, 21B]

4.1. Limitations and Standards

4.1.1. The following conditions and requirements are specific to the coal handling operations:

- a. The coal transferred through the facility shall not exceed 2,550,411 tons per year. Compliance with this limit shall be determined as a 12 month rolling total.
- b. Visible emissions from the permanent structures (transfer house L-TH1, Crusher House L-CH, Tripper Transfer L-TH2, and boiler building) that house coal crushers, transfer points of coal conveying equipment and coal storage silos shall not exceed 20% opacity on a 6-minute averaging period. Water vapor is not a visible emission.
[40 CFR §60.254(a)]
- c. The open stockpile SC-5 shall be limited to a maximum storage capacity of 120,000 tons of coal. Fugitive emissions from the stockpile shall be controlled by the use of water cannon as necessary.
- d. All transfer points shall be fully enclosed and equipped with a dust suppression system except for the transfer points located within the boiler building (tripper floor area) and the transfer point feeding the open stockpile SC-5.
- e. All transfer points and crushers except for the transfer point feeding the stockpile shall be located in permanent structure.
- f. The six (6) coal storage silos shall be enclosed and vent to dust collector CC-21 (L-DC1).
 1. Emissions of PM from dust collector CC-21 (L-DC1) emitted to the atmosphere at emission point EC-21 shall not exceed 0.34 lb/hr and 1.35 TPY.
 2. Emissions of PM-10 from dust collector CC-21 (L-DC1) emitted to the atmosphere at emission point EC-21 shall not exceed 0.29 lb/hr and 1.15 TPY.
 3. Visible emissions from emission point EC-21 shall not exceed 20 percent opacity on a 6 minute average. Water vapor is not a visible emission.
[40 CFR §60.254(a)]

[45CSR14, R14-0024 §4.1.1.; 45CSR16; 40 CFR 60 Subpart Y]

- 4.1.2. **Operation and Maintenance of Air Pollution Control Equipment.** The permittee shall, to the extent practicable, install, maintain, and operate all pollution control equipment listed in Section 1.0 and associated monitoring equipment in a manner consistent with safety and good air pollution control practices for minimizing emissions, or comply with any more stringent limits set forth in this permit or as set forth by any State rule, Federal regulation, or alternative control plan approved by the Secretary.
[45CSR14, R14-0024 §4.1.2.]

4.2. Monitoring Requirements

- 4.2.1. The permittee shall conduct visible emission checks in accordance with the Condition 3.2.1. of this permit for the purpose of ongoing compliance with the visible emission standards (4.1.1.b. and 4.1.1.f.3.) from the coal crushers, conveying equipment and coal storage silos. Refer to Table A in Appendix B of this permit for a list of sources.

[45CSR14, R14-0024 §4.2.1.]

- 4.2.2. For the purposes of demonstrating compliance with the requirements in Conditions 4.1.1.a. and 4.1.1.c., the permittee shall monitor and record the daily amount of coal delivered to this facility. Records of such monitoring shall be maintained in accordance with Condition 3.4.1. of this permit.

[45CSR14, R14-0024 §4.2.2.]

4.3. Testing Requirements

- 4.3.1. Whenever ordered by the Director, the permittee shall conduct performance test(s) to determine compliance with items b and f.3. of Condition 4.1.1. and 40 CFR §60.254(a). Refer to Table A in Appendix B of this permit for a list of sources. Such performance tests (observations) shall be conducted in accordance with Reference Method 9 of Appendix A-4 of 40 CFR 60, with the exceptions as follows:

- a. The duration of the Method 9 of Appendix A-4 of 40 CFR 60 performance test shall be 1 hour (ten 6-minute block averages).
- b. If, during the initial 30 minutes of the observation of a Method 9 performance test, all of the 6-minute block average opacity readings are less than or equal to half the applicable opacity limit, the observation period may be reduced from one hour to 30 minutes.
- c. To determine opacity for fugitive coal dust emissions sources, the following measures must be used:
 1. The minimum distance between the observer and the emission source shall be 16 feet and the sun shall be oriented in the 140-degree sector of the back.
 2. The observer shall select a position that minimizes interference from other fugitive coal dust emissions sources and make observations such that the line of vision is approximately perpendicular to the plume and wind direction.
 3. The observer shall make opacity observations at the point of greatest opacity in that portion of the plume where condensed water vapor is not present.

[45CSR14, R14-0024 §4.3.1.; 45CSR16; 40CFR§§60.8(a) and (b), 60.257(a)]

4.4. Recordkeeping Requirements

- 4.4.1. **Record of Monitoring.** The permittee shall keep records of monitoring information as specified in Condition 3.4.2.

[45CSR14, R14-0024 §4.4.1.]

- 4.4.2. **Record of Maintenance of Air Pollution Control Equipment.** For all pollution control equipment listed in Section 1.0, the permittee shall maintain accurate records of all required pollution control equipment inspection and/or preventative maintenance procedures.

[45CSR14, R14-0024 §4.4.2.]

- 4.4.3. **Record of Malfunctions of Air Pollution Control Equipment.** For all air pollution control equipment listed in Section 1.0, the permittee shall maintain records of the occurrence and duration of any malfunction or operational shutdown of the air pollution control equipment during which excess emissions occur. For each such case, the following information shall be recorded:

- a. The equipment involved.
- b. Steps taken to minimize emissions during the event.
- c. The duration of the event.
- d. The estimated increase in emissions during the event.

For each such case associated with an equipment malfunction, the additional information shall also be recorded:

- e. The cause of the malfunction.
- f. Steps taken to correct the malfunction.
- g. Any changes or modifications to equipment or procedures that would help prevent future recurrences of the malfunction.

[45CSR14, R14-0024 §4.4.3.]

4.5. Reporting Requirements

- 4.5.1. Within 60 days after completing performance testing as required in 4.3.1. and in accordance with 40 CFR §60.258(d), the permittee shall report the result of such testing to the Director and either successfully enter the test data into EPA's WebFire data base or mail a copy to:

United States Environmental Protection Agency
Energy Strategies Group - Mail Code: D243-01
109 TW Alexander Dr.
RTP, NC 27711

[45CSR14, R14-0024 §4.5.1.; 45CSR16; 40 CFR §60.258(d); 45 CSR §13-6.1]

4.6. Compliance Plan

- 4.6.1. NA

5.0 PC Boiler And Cooling Tower [emission point ID(s): EA-1 and ET-1]

5.1. Limitations and Standards

5.1.1. The following conditions and requirements are specific to the PC Boiler (ID #SB-1):

- a. The annual heat input of the PC Boiler shall not exceed 53,558,640 MMBtu per rolling 12-month total. The hourly heat input shall be determined as the hourly average heat input for each operating day, as determined via methods in 40 CFR 75 Appendix F.

[45CSR14, R14-0024 §5.1.1.]

5.1.2. Emissions of nitrogen oxides (NO_x) shall be controlled with the use of low NO_x burners and selective catalytic reduction control technologies. NO_x emissions emitted to the atmosphere from the PC Boiler Stack (EP #EA-1) shall not exceed the following limits to the corresponding averaging periods.

Table 5.1.2. Limits of Nitrogen Oxides from the PC Boiler		
Limit	Terms (Units)	Averaging Period
489	Pounds/hour	24-hour rolling average
428	Pounds/hour	30-day rolling average
1.0 (NSPS Da Limit) *	Pound/MWh	30-day rolling average
397	Pounds/hour	Calendar Year
0.065	Pounds/MMBtu	Calendar Year

*[40 CFR §60.44Da(e)(1)]

Compliance with the NSPS Da limit in Table 5.1.2. shall be determined by calculating the NO_x emissions as 1.194×10^{-7} lb/scf –ppm times the average hourly NO_x output concentration in ppm (measured according to the provisions of 40CFR §60.49Da(c)), times the average hourly flow rate (measured in scfh, according to the provisions of 40 CFR §60.49Da(m)), divided by the average hourly gross energy output (measured according to the provisions of 40 CFR §60.49Da(k)).

[40 CFR §60.48Da(i)]

[45CSR14, R14-0024 §5.1.2.; 45CSR16; 40 CFR 60 Subpart Da]

5.1.3. Emissions of sulfur dioxides (SO₂) shall be controlled with the use of a wet flue gas desulfurization control technology. SO₂ emissions emitted to the atmosphere from the PC Boiler Stack (EP #EA-1) shall not exceed the following limits to the corresponding averaging periods.

Table 5.1.3. Limits of Sulfur Dioxide from the PC Boiler		
Limit	Terms	Averaging Period
917	Pounds/hour	3-hour rolling average
734	Pounds/hour	24-hour rolling average
1.4 (NSPS Da Limit)*	Pound/MWh	30-day rolling average
581	Pounds/hour	Calendar Year
0.095	Pounds/MMBtu	Calendar Year

Table 5.1.3. Limits of Sulfur Dioxide from the PC Boiler		
Limit	Terms	Averaging Period
2,417	Tons/year	Calendar Year

***[40 CFR §60.43Da(i)(1)]**

Compliance with the NSPS Da limit in Table 5.1.3. shall be determined by calculating the SO₂ emissions as 1.660×10^{-7} lb/scf –ppm times the average hourly SO₂ output concentration in ppm (measured according to the provisions of 40CFR §60.49Da(b)), times the average hourly flow rate (measured in scfh, according to the provisions of 40 CFR §60.49Da(m)), divided by the average hourly gross energy output (measured according to the provisions of 40 CFR §60.49Da(k)).

[40 CFR §60.48Da(m)]

Compliance with the 30-day rolling average limits listed in Table 5.1.2. and Table 5.1.3. is determined by calculating the arithmetic average of all hourly emission rates for NO_x and SO₂ for the 30 successive operating days, except for data obtained during startup, shutdown, or malfunction.

[40 CFR §60.48Da(d)]

[45CSR14, R14-0024 §5.1.3.; 45CSR16, 40 CFR 60 Subpart Da]

- 5.1.4. Emissions of particulate matter (PM) shall be controlled with fabric filter control technology. Emissions to the atmosphere from the PC Boiler Stack (EP #EA-1) shall not contain PM in excess of either:

- a. 0.14 lb/MWh gross energy output; or
- b. 0.015 lb/MMBtu heat input derived from the combustion of solid, liquid, or gaseous fuel.

Compliance with this streamlined lb/MMBtu PM emission limit assures compliance with 45CSR §2-4.1.a.

[40CFR§§60.42Da(c)(1) and (2)]

Compliance with either limit shall be determined by calculating the arithmetic average of all hourly emission rates for PM each operating day, except for data obtained during startup, shutdown, and malfunction. Averages are only calculated for operating days that have valid data for at least 18 hours of unit operation during which the limitation applies. All of the valid hourly emission rates of the operating day(s) not meeting the minimum 18 hours valid data daily average requirements are averaged with all of the valid hourly emission rates of the next operating day with 18 hours or more of valid PM CEMS data to determine compliance.

[40 CFR §60.48Da(f)]

The average hourly PM emission rate shall be calculated by multiplying the average hourly PM output concentration (measured according to 40CFR §60.49Da(t)), by the average hourly flow rate (measured in scfh, according to the provisions of 40 CFR §60.49Da(m)), and divided by the average hourly gross energy output, as applicable (measured according to the provisions of 40 CFR §60.49Da(k)).

[40CFR §60.48Da(n)]

[45CSR14, R14-0024 §5.1.4.; 45CSR16; 40 CFR 60 Subpart Da; 45CSR§2-4.1.a.]

- 5.1.5. Emissions of particulate matter less than ten microns (PM₁₀) shall be controlled with fabric filter control technology. PM₁₀ emissions (includes the filterable and condensable fractions other than water) emitted to

the atmosphere from the PC Boiler Stack (EP #EA-1) shall not exceed 110 lb/hr based on a six-hour rolling average.

[45CSR14, R14-0024 §5.1.5.]

- 5.1.6. Emissions of carbon monoxide (CO) shall be controlled with the use of good combustion practices control technology. CO emissions emitted to the atmosphere from the PC Boiler Stack (EP #EA-1) shall not exceed 673 lb/hr (0.11 lb/MMBtu) based on a twenty-four hour rolling average.

[45CSR14, R14-0024 §5.1.6.]

- 5.1.7. Emissions of volatile organic compounds (VOC) shall be controlled with the use of good combustion practices control technology. VOC emissions emitted to the atmosphere from the PC Boiler Stack (EP #EA-1) shall not exceed 24.5 lb/hr (0.004 lb/MMBtu) based on a three-hour rolling average.

Continuous compliance with this emission limit shall be determined by using the data generated by CO CEMS as a surrogate for VOC. The permittee shall establish through testing the relationship between CO emissions and VOC emissions. An exceedance based on the CEMS data for CO and the relationship between CO and VOCs constitutes an exceedance of this emission limit for VOC. The permittee shall have the option to perform emission testing to verify the relationship between CO and VOC if the CEM data for CO indicates an exceedance of the VOC emission limit. Testing performed after the exceedance to determine whether the underlying relationship between CO and VOC has changed shall not be an absolute defense to the exceedance.

[45CSR14, R14-0024 §5.1.7.]

- 5.1.8. Emissions of sulfuric acid mist (H₂SO₄) shall be controlled with the use of dry sorbent injection in conjunction with fabric filter control technology. H₂SO₄ emissions emitted to the atmosphere from the PC Boiler Stack (EP #EA-1) shall not exceed 45.8 lb/hr (0.0075 lb/MMBtu) based on a 3-hour rolling average.

Continuous compliance with this emission limit shall be determined by using the data generated by SO₂ CEMS as a surrogate for H₂SO₄. The permittee shall establish through testing the relationship between SO₂ emissions and H₂SO₄ emissions. An exceedance based on the CEMS data for SO₂ and the relationship between SO₂ and H₂SO₄ constitutes an exceedance of this emission limit for H₂SO₄. The permittee shall have the option to perform emission testing to verify the relationship between SO₂ and H₂SO₄ if the CEM data for SO₂ indicates an exceedance of the H₂SO₄ emission limit. Testing performed after the exceedance to determine whether the underlying relationship between SO₂ and H₂SO₄ has changed shall not be an absolute defense to the exceedance.

[45CSR14, R14-0024 §5.1.8.]

- 5.1.9. Emissions of mercury (Hg) from the PC Boiler Stack (EP #EA-1) shall not exceed 1.3E⁻² pounds per GWh (gross electric power out from the generator) based on a thirty (30) boiler operating day rolling average with the 12-month rolling total not to exceed 4.38E⁻² TPY (equates to 87.6 pounds per year) based on 12 month rolling average. The 30 boiler operating day rolling average limit shall apply at all times except during periods of startup and shutdown. Each 30 boiler operating day rolling average shall be calculated according to Section 6.2 of Appendix A to Subpart UUUUU of Part 63. Compliance with the limit will be demonstrated by using Hg CEMs output data collected during all non-exempt boiler operating hours.

[45CSR14, R14-0024 §5.1.9.; 45CSR34; 40CFR§63.9991(a)(1); Table 2 to Subpart UUUUU of Part 63; §63.10000(a); and §63.10010(g)]

- 5.1.10. Emissions of total non-mercury (Hg) HAP metals from the PC Boiler Stack (EP #EA-1) shall not exceed 0.50 pound per GWh (gross electric power out from the generator) based on a thirty boiler operating day rolling average with the 12-month rolling total not to exceed 1.69 tons. The 30 boiler operating day rolling average limit shall apply at all times except during periods of startup and shutdown. Each 30 boiler operating day rolling average shall be calculated according to Table 7 to Subpart UUUUU. Compliance with the limit will be demonstrated by using PMCEMs output data demonstrating compliance with a PM rate at or less than 0.3 lb per MWh on an arithmetic 30-boiler operating day rolling average using the hourly average PM CEMS output data collected during all non-exempt boiler operating hours.
[45CSR14, R14-0024 §5.1.10.; 45CSR34; 40CFR§63.9991(a)(1); Tables 2 and 7 to Subpart UUUUU of Part 63; §63.10000(a) and §63.10010(i)]
- 5.1.11. Emissions of hydrochloric acid (HCL) shall be controlled with the use of dry sorbent injection in conjunction with fabric filter control technology. Emissions of HCL from the PC Boiler Stack (EP #EA-1) shall not exceed 0.02 lb/MWh (gross electric power out from the generator) on a 30 boiler operating day rolling average with the 12-month rolling total not to exceed 4.46 tons. The 30 boiler operating day rolling average limit shall apply at all times except during periods of startup and shutdown. Compliance with the 30 boiler operating day rolling average shall be demonstrated by using SO₂ CEMS output data demonstrating compliance with a SO₂ rate at or less than 1.5 lb per MWh on a 30 day rolling average basis. Each 30-boiler operating day rolling average emission rate is the average of all of the valid SO₂ emission rates in the preceding 30 boiler operating days.
[45CSR14, R14-0024 §5.1.11.; 45CSR34; 40CFR§§63.9991(a)(1) and, (c); Table 2 to Subpart UUUUU of Part 63; §63.10000(a) and §63.10010(f)]
- 5.1.12. Emissions of hydrofluoric acid (HF) shall be controlled with the use of dry sorbent injection in conjunction with fabric filter control technology. Emissions of HF from the PC Boiler Stack (EP #EA-1) shall not exceed a 12-month rolling total of 1.28 tons.
[45CSR14, R14-0024 §5.1.12.]
- 5.1.13. Visible emissions from the PC Boiler (EP #EA-1) shall not exceed 10% opacity on a 6-minute block averaging period.
[45CSR14, R14-0024 §5.1.13.; 45CSR§2-3.1.]
- 5.1.14. *[Reserved]*
- 5.1.15. The conditions and requirements in the following subdivisions are specific to the mechanical draft cooling tower (ID #ST-1):
- a. Emissions of PM and PM-10 shall be controlled with a 0.002% drift eliminator or an equivalent control technology. PM/PM₁₀ emissions emitted to the atmosphere from the Cooling Tower (EP #ET-1) shall not exceed 4.1 lb/hr and 13.7 TPY.
[45CSR14, R14-0024 §5.1.15.]
- 5.1.16. **Operation and Maintenance of Air Pollution Control Equipment.** The permittee shall, to the extent practicable, install, maintain, and operate all pollution control equipment listed in Section 1.0 and associated monitoring equipment in a manner consistent with safety and good air pollution control practices for minimizing emissions, or comply with any more stringent limits set forth in this permit or as set forth by any State rule, Federal regulation, or alternative control plan approved by the Secretary.
[45CSR14, R14-0024 §5.1.16.; 45CSR§2-9.2]

- 5.1.17. The addition of sulfur oxides to a combustion unit (i.e., PC Boiler SB-1) exit gas stream for the purpose of improving emissions control equipment is prohibited unless written approval for such addition is provided by the Secretary.-
[45CSR§2-4.4.]
- 5.1.18. Except for the requirements in conditions 5.1.9., 5.1.10., and 5.1.11., the coal-fired Electric Utility Steam Generating Unit SB-1 shall comply with all applicable requirements for existing affected sources, pursuant to 40 CFR 63, Subpart UUUUU “National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units” no later than the existing source compliance date of April 16, 2015, or as amended by US EPA.
[45CSR34; 40 CFR §63.9984(b)]
- 5.1.19. If required to conduct an initial compliance demonstration by performance testing as specified in §63.10011(a), you must submit a Notification of Compliance Status (NOCS) report according to §63.9(h)(2)(ii). The NOCS report must contain all of the information specified in §63.10030(e)(1)-(7), as applicable. If required to submit a Notification of Compliance Status pursuant to 40 CFR 63, Subpart UUUUU, the permittee shall also submit a complete application for a modification to the Title V permit to incorporate the specific requirements of the rule no later than the maximum time allowed for the NOCS submittal in 40 C.F.R. §63.10030(e). If requested, this Title V permitting deadline may be changed upon written approval by the Director. The permittee shall request the change in writing at least 30 days prior to the application due date.
[45CSR34; 40 CFR 63, Subpart UUUUU, 45CSR§30-6.5.b.]

5.2. Monitoring Requirements

- 5.2.1. *Continuous Monitoring Requirements:* The permittee shall install, calibrate, maintain and operate CEMS, and a diluent monitor to measure and record the emissions of PM, SO₂, NO_x, CO, Hg and other parameters to determine compliance from the boiler stack (EP #EA-1) in a manner sufficient to demonstrate continuous compliance with the CEMS-based emission standards in Section 5.1. of this permit. These CEMS shall be installed, calibrated, properly functioning, and certified in accordance with the following requirements:
- a. *PM CEMS:* The PM CEMS shall be installed and operated in accordance with Performance Specification (PS) 11 in appendix B of 40CFR60. During the correlation testing runs as required by PS 11, PM and CO₂ or O₂ data shall be collected concurrently (or within a 30 to 60 minute period) by both the continuous emissions monitors and performance tests conducted using the following test methods:
1. Method 5 or 5B of appendix A-3 of 40CFR60 or Method 17 of appendix A-6 of 40CFR60 shall be used for determining PM emissions;
 2. Method 3A or 3B of appendix A-2 of 40CFR60 shall be used for determining either O₂ or CO₂.
 3. Quarterly accuracy determinations and daily calibration drift tests shall be performed in accordance with Procedure 2 in appendix F of 40CFR60. The permittee shall perform Relative Response Audits on an annual basis and a Response Correlation Audits once every three (3) years. Records of such quarterly accuracy determinations, daily calibration drift tests, relative response

audits, and response correlation audits must be maintained in accordance with Condition 3.4.1. of this permit.

[40 CFR §§60.49Da(v); 40 CFR§§64.3(b)(1) and (b)(4)(ii); 45CSR§2-8.1.; 45CSR§2A-5.2]

- b. *SO₂ CEMS*: The SO₂ CEMS shall be certified, operated, and maintained in accordance with the requirements of 40 CFR 75 provided that the requirements of 40CFR§60.49Da(b)(4)(i – iii) are met. Record keeping and reporting shall be conducted pursuant Subparts F and G in 40 CFR 75.

[40 CFR §60.49Da(b)(4)]

- c. *NO_x CEMS*: The NO_x CEMS shall be certified, operated, and maintained in accordance with the requirements of 40 CFR 75.

[40 CFR §60.49Da(c)(2)]

- d. *CO CEMS*: The CO CEMS shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4 or 4A. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report of Section 7 shall be made each calendar quarter, to be submitted with respective semi-annual reports required by Condition 5.5.3. The RATA tests required for the CO monitor shall be performed using EPA Method 10 in Appendix A of 40 CFR 60. The CO monitor span values shall be set appropriately, considering the allowable methods of operation and corresponding emission standards.

- e. *Hg CEMS*: The Hg CEMS shall be certified, operated, and maintained in accordance with the requirements of Performance Specifications (PS) 12A in Appendix B of 40CFR Part 60.

1. The permittee must conduct a performance evaluation of the Hg CEMS according to the requirements of 40CFR§60.13 and PS 12A.
2. The CEMS must complete a minimum of one cycle of operation (samplings, analyzing, and data recording) for each successive 15-minute period.
3. The permittee shall use all valid data points collected during the hour to calculate the hourly average Hg concentration.
4. The CEMS shall be operated and maintained in a manner to obtain data for at least 75 percent of the unit operating hours (PC Boiler) in the month.
5. After April 16, 2015, the Hg CEMs must be certified, operated, maintained and quality-assure the data from the monitoring system in accordance with Appendix A of 40 CFR Part 63.

[40 CFR §63.10010(g)]

- f. *Diluent Monitor*: The oxygen (O₂) or carbon dioxide (CO₂) content of the flue gas shall be monitored at the location where CO and NO_x are monitored. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 60 or 40 CFR 75.

- g. *Flow Monitor*: The volumetric flow rate of the flue gas shall be monitored at the location where CO and NO_x are monitored. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75.

[40 CFR §60.49Da(m)]

- h. *Gross Output*: A wattmeter, device to measure gross amount of electricity generation by the STG, shall be installed, calibrated, maintained, and operated on a continuous basis.

[40 CFR §60.49Da(k)(1)]

[45CSR14, R14-0024 §5.2.1.; 45CSR16; 40 CFR 60 Subpart Da; 45CSR34; 40 CFR 63 Subpart UUUU; 45CSR§13-6.2.; 40 CFR 64; 45CSR§30-5.1.c.; 45CSR2 and 2A]

5.2.2. *[Reserved]*

- 5.2.3. The permittee shall install, certify, operate, and maintain the SO₂, NO_x, and CO₂ or O₂ CEMS as specified in 40CFR§§60.49Da(w)(1) through (w)(5). (EP #EA-1)

[45CSR14, R14-0024 §5.2.3.]

- 5.2.4. Data reported to meet the requirements of 40 CFR §60.51Da shall not include data substituted using the missing data procedures in Subpart D of 40 CFR 75, nor shall the data have been bias adjusted according to the procedures of 40 CFR 75. (EP #EA-1)

[45CSR14, R14-0024 §5.2.4.; 45CSR16; 40 CFR §§60.49Da(b)(4)(iii) and (c)(2)]

- 5.2.5. The permittee shall sample the coal consumed by the PC Boiler (SB-1) on a biweekly basis. These sample(s) shall be analyzed to determine the concentrations of beryllium, chlorine, fluorine, and lead. Records of such analyses shall be maintained in accordance with Condition 3.4.1 of this permit.

[45CSR14, R14-0024 §5.2.5.]

- 5.2.6. For the purpose of determining compliance with the emission limit in Condition 5.1.15., the permittee shall monitor flow and either the concentration of total dissolved solids contained in the circulating water of the cooling tower or specific conductivity on a daily basis. If the permittee uses a correlation curve or ratio between total dissolved solids concentration and specific conductivity, the Director or his/her representative may request the permittee to verify the correlation at any reasonable time with just cause. The permittee shall determine the PM, and PM₁₀ emissions from the cooling towers using a method that accurately predicts these specific pollutants from mechanical draft cooling towers. Such determination shall be conducted on a monthly basis. Records of such monitoring and determinations shall be maintained in accordance with Condition 3.4.1. of this permit.

[45CSR14, R14-0024 §5.2.6.]

- 5.2.7. Should the permittee have to use other data systems other than PM CEMS data to satisfy the 75 percent of total operating hours per 30 day rolling average, at the minimum the permittee shall determine the opacity from PC boiler stack in accordance with Method 9 to demonstrate compliance with the visible emission standard of Condition 5.1.13. within the 30 day reporting period that other data systems are used. Records of the said observations shall be maintained in accordance with Condition 3.4.1. of this permit.

[45CSR14, R14-0024 §5.2.7.; 45CSR§2-8.1]

- 5.2.8. Whenever any 24-hour block average PM rate based on PM CEM data indicates an excursion of the hourly PM limit of 5.1.4., the permittee shall conduct a visible emission observation in accordance with Method 9 of appendix A-4 of 40CFR Part 60 for a minimum of six minutes as soon as practical but no later than 24

hours of the last hour of the excursion. Such observation shall continue for each hour until four (4) successive six-minute block observations demonstrate compliance or two (2) successive observations demonstrate compliance and PM CEM data during the same two hours indicates compliance with the hourly PM limit of 5.1.4. Records of such observations and PM CEM data shall be maintained in accordance with Condition 3.4.1 of this permit.

[45CSR14, R14-0024 §5.2.8.]

- 5.2.9. **Commencement of operation (CAM)** – The permittee shall conduct the monitoring for PM₁₀ as required under 40 C.F.R. Part 64 upon the effective date of this permit.

[40 C.F.R. §64.7(a); 45CSR§30-5.1.c.]

- 5.2.10. **Excursions (CAM)** – An excursion shall be defined as a 6-hr rolling average PM rate above the hourly PM₁₀ limit of 5.1.5. (PC Boiler *SB-1*)

[40 C.F.R. §64.6(c)(2); 45CSR§30-5.1.c.]

- 5.2.11. **Proper Maintenance (CAM)** - At all times, the permittee shall maintain the monitoring, including but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment. (PC Boiler *SB-1*)

[40 C.F.R. §64.7(b); 45CSR§30-5.1.c.]

- 5.2.12. **Continued Operation (CAM)** – Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permittee shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of 40 C.F.R. Part 64, including data averages and calculations, or fulfilling a minimum data availability requirement, if applicable. The owner or operator shall use all the data collected during all other periods in assessing the operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions. (PC Boiler *SB-1*)

[40 C.F.R. §64.7(c); 45CSR§30-5.1.c.]

- 5.2.13. **Response to Excursions or Exceedances (CAM)**

- a. Upon detecting an excursion or exceedance, the permittee shall restore operation of the pollutant-specific emissions unit (i.e., PC Boiler *SB-1*), including the control device and associated capture system, to its/their normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Such actions may include initial inspection and evaluation, recording that operations returned to normal without operator action (such as through response by a computerized distribution control system), or any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.
- b. Determination of whether the permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include but is not limited to, monitoring

results, review of operation and maintenance procedures and records, and inspection of the control device, associated capture system, and the process.

[40 C.F.R. §64.7(d); 45CSR§30-5.1.c.]

- 5.2.14. **Documentation of Need for Improved Monitoring (CAM)** – After approval of monitoring under 40 C.F.R. Part 64, if the permittee identifies a failure to achieve compliance with an emission limitation or standard for which the approved monitoring did not provide an indication of an excursion or exceedance while providing valid data, or the results of compliance or performance testing document a need to modify the existing indicator ranges or designated conditions, the permittee shall promptly notify the Director and, if necessary, submit a proposed modification to the permit to address the necessary monitoring changes. Such a modification may include, but is not limited to, reestablishing indicator ranges or designated conditions, modifying the frequency of conducting monitoring and collecting data, or the monitoring of additional parameters. (PC Boiler *SB-1*)

[40 C.F.R. §64.7(e); 45CSR§30-5.1.c.]

5.3. Testing Requirements

- 5.3.1. *For the testing requirements of 5.3.4. and 5.3.6.:* Tests shall be conducted at a heat input rate of no less than 90 % of the maximum permitted heat input rate of the unit. CEMS data for PM, NO_x, SO₂, CO, Hg, volumetric flow and O₂ or CO₂ shall be reported for each run of the required tests. The hourly heat input of PC boiler and electric output of the generator shall be measured and recorded for each test run. The Director may require the permittee to repeat some or all of initial stack tests after major replacement or major repair of any air pollution control or process equipment. Such testing shall be conducted in accordance with Condition 3.3.1. of this permit.

[45CSR14, R14-0024 §5.3.1. 45CSR§30-5.1.c.]

- 5.3.2. *Test Methods:* Any required test shall be performed in accordance with the following methods unless an alternative method is approved by the Director or unless otherwise specified:

Table 5.3.2. Tests Methods for the Boiler Stack	
EPA Method	Description of Method and Comments
1 - 4	Determination of Traverse Point, Velocity and Flow Rate, Gas Analysis, and Moisture Content {Notes: Methods shall be performed as necessary to support other methods.}
5, 5B, 5I	Measurement of PM
6C	Measurement of SO ₂ Emission (Instrumental)
7E	Measurement of NO _x Emissions (Instrumental)
9	Visual Determination of the Opacity
10	Measurement of CO Emission (Instrumental)
18	Measurement of Gaseous Organic Compound Emissions (Gas Chromatography) {For concurrent use with EPA Method 25A to deduct emissions of methane and ethane from the THC emissions measured by Method 25A.}
19	Calculation Method for NO _x , PM, and SO ₂ Emission Rate
25	Determination of Total Gaseous Non-methane Organic Emission as Carbon

Table 5.3.2. Tests Methods for the Boiler Stack	
EPA Method	Description of Method and Comments
25A	Measurement of Gaseous Organic Concentrations (Flame Ionization)
26A	Determination of Hydrogen Halide And Halogen Emissions From Stationary Sources Isokinetic Method
29	Determination of Metals Emissions From Stationary Sources
201, 201A, 202	Measurement of PM ₁₀ and Condensable PM
320	Measurement of Vapor Phase Organic and Inorganic Emissions By Extractive Fourier Transform Infrared (FTIR) Spectroscopy (may be used in lieu of 26A to measure HCL and HF)
OTM27	Determination of PM ₁₀ and PM _{2.5} Emissions From Stationary Sources
OTM28	Dry Impinger Method for Determining Condensable PM Emissions From Stationary Sources
ASTM D6348-03	Standard Test Method for Determination of Gaseous Compounds by Extractive Director Fourier Transform Infrared (FTIR) (may be used in lieu of 26A to measure HCL and HF)
ASTM D6784-02	Standard Test Method for Elemental, Oxidized, Particle-Bound and Total Mercury in Flue Gas Generated from Coal-Fired Stationary Sources (Ontario Hydro Method)
CTM-13B	Modified Controlled Condensation Method for Measuring Sulfuric Acid Emissions from Kraft Recovery Furnaces and Boilers with Wet Particulate Matter Control Devices

[45CSR14, R14-0024 §5.3.3.]

- 5.3.3. The permittee shall verify compliance with emission limits for PM₁₀, VOCs, and H₂SO₄ by conducting performance testing once every twelve (12) months from the initial compliance determination as required in Condition 5.3.1. of permit R14-0024. “Once every twelve months” is defined as to be within 11 to 13 calendar months after the previous performance test. Such testing shall be conducted in accordance with Conditions 3.3.1., 5.3.1., and 5.3.3. of this permit. Records of such testing shall be maintained in accordance with Condition 3.4.1 of this permit.

[45CSR14, R14-0024 §5.3.3.]

- 5.3.4. The permittee shall perform periodic drift testing once every five years on the cooling towers. Such testing shall be conducted in accordance with Condition 3.3.1. of this permit. Records of such testing shall be maintained in accordance with Condition 3.4.1 of this permit.

[45CSR14, R14-0024 §5.3.4.]

- 5.3.5. The permittee shall determine the overall removal efficiency for HCl and HF by conducting performance testing twelve (12) months from the initial compliance determination as required in Condition 5.3.1. of permit R14-0024. “Twelve months” is defined as to be within 11 to 13 calendar months after the previous performance test. After such testing, the timing for follow-up testing shall be determined on actual 12-month rolling total of HCL and HF emission. If the 12-month rolling total is above 80% of the permitted 12-month rolling total limit after 12 months from the most recent testing, then the permittee shall repeat such testing. Such testing shall be conducted in accordance with Conditions 3.3.1., 5.3.1., and 5.3.3. of this permit. Records of such testing shall be maintained in accordance with Condition 3.4.1 of this permit.

[45CSR14, R14-0024 §5.3.5.]

5.4. Recordkeeping Requirements

- 5.4.1. **Record of Monitoring.** The permittee shall keep records of monitoring information as specified in Condition 3.4.2.

[45CSR14, R14-0024 §5.4.1.]

- 5.4.2. **Record of Maintenance of Air Pollution Control Equipment.** For all pollution control equipment listed in Section 1.0, the permittee shall maintain accurate records of all required pollution control equipment inspection and/or preventative maintenance procedures.

[45CSR14, R14-0024 §5.4.2.]

- 5.4.3. **Record of Malfunctions of Air Pollution Control Equipment.** For all air pollution control equipment listed in Section 1.0, the permittee shall maintain records of the occurrence and duration of any malfunction or operational shutdown of the air pollution control equipment during which excess emissions occur. For each such case, the following information shall be recorded:

- a. The equipment involved.
- b. Steps taken to minimize emissions during the event.
- c. The duration of the event.
- d. The estimated increase in emissions during the event.

For each such case associated with an equipment malfunction, the additional information shall also be recorded:

- e. The cause of the malfunction.
- f. Steps taken to correct the malfunction.
- g. Any changes or modifications to equipment or procedures that would help prevent future recurrences of the malfunction.

[45CSR14, R14-0024 §5.4.3.]

- 5.4.4. The permittee shall record the amounts of each fuel consumed by the PC boiler during each operating day. Such records shall be maintained in accordance with Condition 3.4.1. of this permit.

[45CSR14, R14-0024 §5.4.4., 45CSR§2-8.3.c.; 45CSR§2A-7.1.a.]

- 5.4.5. The permittee shall determine and record the ash and Btu content of the coal received at the facility. Such records shall be maintained in accordance with Condition 3.4.1. of this permit.

[45CSR14, R14-0024 §5.4.5.; 45CSR§2-8.3.c.; 45CSR§2A-7.1.a.4.]

- 5.4.6. The permittee shall maintain records of the date and time of start-up and shut-down.

[45CSR§2-8.3.c.; 45CSR§2A-7.1.a.4.]

- 5.4.7. **General recordkeeping requirements for 40 C.F.R. Part 64 (CAM)**

The permittee shall comply with the recordkeeping requirements specified in permit conditions 3.4.1. and 3.4.2. The permittee shall maintain records of monitoring data, monitor performance data, corrective

actions taken, any written quality improvement plan required pursuant to 40 C.F.R. §64.8 and any activities undertaken to implement a quality improvement plan, and other supporting information required to be maintained under 40 C.F.R. Part 64 (such as data used to document the adequacy of monitoring, or records of monitoring maintenance or corrective actions).

[40 CFR §64.9(b); 45CSR§30-5.1.c.]

5.5. Reporting Requirements

- 5.5.1. Within 90 days after completing a PM CEMS performance evaluation as required by and in accordance with 40 CFR 60.49Da(v), the permittee shall either successfully enter the test data into EPA's WebFire data base or mail a copy to:

United States Environmental Protection Agency
Energy Strategies Group - Mail Code: D243-01
109 TW Alexander Dr.
RTP, NC 27711

[45CSR14, R14-0024 §5.5.1., 40 CFR §60.49Da(v)(4)]

- 5.5.2. Within 60 calendar days after completing any testing as required in Section 5.3. or performance evaluation of a CEMS as required in Section 5.2. of this permit, the permittee shall report the results or findings of such testing or evaluation to the Director.

[45CSR14, R14-0024 §5.5.2.; 45CSR16; 40 CFR §60.51Da(a); 45CSR§§13-6.1 and 2.]

- 5.5.3. The permittee shall submit semiannual reports to the Director concerning emissions from the PC Boiler. The reporting periods for such reports shall be for the 1st half of the calendar year is from January 1st to June 30th and the 2nd half of the year is July 1st to December 31st. These reports shall be postmarked no later than 30th day after the end of the reporting period. Such reports shall contain the following information:

For each 24 hour period:

- a. Calendar date;
- b. The average SO₂ and NO_x (lb/MWh) for each 30 successive unit operating days, ending with the last 30 day period in the quarter; reason for non-compliance with the emission standards; and, description of corrective actions taken.
- c. Identification of the unit operating date for which pollutant or diluents data have not been obtained by an approved method for at least 75 percent of the hours of operation of the facility; justification for not obtaining sufficient data; and description of corrective actions taken. Identification of the times when emission data have been excluded from the calculation of average emission rates because of startup, shutdown, malfunction or other reasons, and justification for excluding data for reasons other than startup, shutdown, malfunction, or emergency conditions.
- d. Identification of the "F" factor used for calculations, method of determination, and type of fuel combusted.

- e. Identification of the times when hourly averages have been obtained based on manual sampling methods.
- f. Identification of the times when the pollutant concentration exceeded full span of the CEMS.
- g. Description of any modifications to CEMS which could affect the ability of the CEMS to comply with Performance Specifications 2 or 3.
- h. If the minimum quantity of emissions data as required by 40 CFR §60.49Da is not obtained for any 30 successive unit operating days, the following information shall be included in the quarterly report of the respective reporting period.
 - 1. The number of hourly average available for outlet emission rates.
 - 2. The standard deviation of hourly averages for outlet emission rates.
 - 3. The lower confidence limit for the mean outlet emission rate.
 - 4. The applicable potential combustion concentration.
 - 5. The ratio of the upper confidence limit for the mean outlet emission rate (E_o^*) and the allowable emission rate (E_{std}) as applicable.
- i. If any standard under 40 CFR §60.43Da (SO₂ NSPS Da standard) is exceeded during emergency conditions because of control system malfunction, the permittee shall submit a signed statement indicating if emergency conditions existed and requirements under 40 CFR §60.48Da(d) were met during each period, and including the following information.
 - 1. Times periods the emergency condition existed;
 - 2. Electrical output and demand on the permittee's electric utility system and the affected facility;
 - 3. Amount of power purchased from interconnected neighboring utility companies during the emergency period;
 - 4. Percent reduction in emissions achieved;
 - 5. Atmospheric emission rate (ng/J and lb/MWh) of the pollutant discharged; and
 - 6. Actions taken to correct control system malfunction.
- j. For periods for which SO₂ or NO_x emissions data are not available, the permittee shall submit a signed statement indicating if any changes were made in operation of the emission control system during the period of data unavailability. Operations of the control system and the pc boiler during the periods of data unavailability are to be compared with operation of the control system and pc boiler before and following the period of data unavailability.

[45CSR14, R14-0024 §5.5.3.; 45CSR16; 40 CFR §60.51Da(f)]

- 5.5.4. *Quarterly PM, CO, Hg Emission Report:* Within 30 days following the end of each quarter, the permittee shall submit a report to the Director summarizing PM, CO, and Hg emissions including periods of startups, shutdowns, malfunctions, and CEMS system monitor availability for the previous quarter. Any emissions data that indicates that the limits as stated in Section 5.1. were exceeded during the corresponding reporting period must be noted in this summary report. At the minimum, the date and time, length of the exceedances(s), magnitude, the limit that was exceeded, the cause of the exceedances, and the corrective action taken shall be included in the summary report.

[45CSR14, R14-0024 §5.5.4.; 45CSR§2A-7.2.c. and 45CSR§13-3]

- 5.5.5. Excess opacity periods resulting from any malfunction of the PC Boiler or its air pollution control equipment, meeting the following conditions, may be reported on a quarterly basis unless otherwise required by the Secretary:

- a. The excess opacity period does not exceed thirty (30) minutes within any twenty-four (24) hour period; and
- b. Excess opacity does not exceed forty percent (40%).

[45CSR§2-9.3.a.]

- 5.5.6. Except as provided in permit condition 5.5.5. above, the owner or operator shall report to the Secretary by telephone, telefax, or e-mail any malfunction of the PC Boiler or its associated air pollution control equipment, which results in any excess 45CSR2 particulate matter (i.e., Rule 2 Limit of 305.7 lb/hr) or excess opacity, by the end of the next business day after becoming aware of such condition. The owner or operator shall file a certified written report concerning the malfunction with the Secretary within thirty (30) days providing the following information:

- a. A detailed explanation of the factors involved or causes of the malfunction;
- b. The date, and time of duration (with starting and ending times) of the period of excess emissions;
- c. An estimate of the mass of excess emissions discharged during the malfunction period;
- d. The maximum opacity measured or observed during the malfunction;
- e. Immediate remedial actions taken at the time of the malfunction to correct or mitigate the effects of the malfunction; and
- f. A detailed explanation of the corrective measures or program that will be implemented to prevent a recurrence of the malfunction and a schedule for such implementation.

[45CSR§2-9.3.b.]

- 5.5.7. **General reporting requirements for 40 C.F.R. Part 64 (CAM)**

- a. On and after the date specified in 40 C.F.R. §64.7(a) (i.e., effective date of this permit) by which the permittee must use monitoring that meets the requirements of 40 C.F.R. 64, the permittee shall submit monitoring reports to the DAQ in accordance with permit condition 3.5.6.

- b. A report for monitoring under 40 C.F.R. 64 shall include, at a minimum, the information required under permit condition 3.5.8. and the following information, as applicable:
 - 1. Summary information on the number, duration and cause (including unknown cause, if applicable) of excursions or exceedances, as applicable, and the corrective actions taken;
 - 2. Summary information on the number, duration and cause (including unknown cause, if applicable) for monitor downtime incidents (other than downtime associated with zero and span or other daily calibration checks, if applicable); and
 - 3. A description of the actions taken to implement a QIP during the reporting period as specified in 40 C.F.R. §64.8. Upon completion of a QIP, the permittee shall include in the next summary report documentation that the implementation of the plan has been completed and reduced the likelihood of similar levels of excursions or exceedances occurring.

[40 C.F.R. § 64.9(a); 45CSR§30-5.1.c.]

- 5.5.8. *Acid Rain Program* – the PC Boiler “SB-1” is a Phase II Acid Rain affected unit under 45CSR33, as defined by 40 C.F.R § 72.6, and as such are required to meet the requirements of 40 C.F.R. Parts 72, 73, 74, 75, 76, 77 and 78. These requirements include, but are not limited to:
 - a. Hold an Acid Rain permit;
 - b. Hold allowances, as of the allowance transfer deadline, in the unit’s compliance sub-account of not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit;
 - c. Comply with the applicable Acid Rain emissions for sulfur dioxide;
 - d. Comply with the applicable Acid Rain emissions for nitrogen oxides;
 - e. Comply with the monitoring requirements of 40 C.F.R. Part 75 and section 407 of the Clean Air Act of 1990 and regulations implementing section 407 of the Act;
 - f. Submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 C.F.R. Part 72, Subpart I and 40 C.F.R. Part 75.

[45CSR33, 40 C.F.R. Parts 72, 73, 74, 75, 76, 77, 78.]

5.6. Compliance Plan

- 5.6.1. NA

6.0 Auxiliary Boiler [emission point ID(s): EX-1]

6.1 Limitations and Standards

6.1.1. The following conditions and requirements are specific to the Auxiliary Boiler (ID #SX-1):

- a. The hourly heat input of the Auxiliary Boiler shall not exceed 225 million British Thermal Units (MMBtu) per hour.
- b. The permittee shall not operate the Auxiliary Boiler greater than 876 hours in a calendar year.
- c. The Auxiliary Boiler shall not consume more than 197.1 million cubic feet of natural gas on an annual basis.
- d. The permittee shall perform annual maintenance of the Auxiliary Boiler.

[45CSR14, R14-0024 §6.1.1.]

6.1.2. Emissions of nitrogen oxides (NO_x) shall be controlled with the use of low NO_x burners and good combustion practices control technologies. NO_x emissions emitted to the atmosphere from the Auxiliary Boiler Stack (EP #EX-1) shall not exceed 22.1 lb/hr based on a three-hour block average.

[45CSR14, R14-0024 §6.1.2.]

6.1.3. Emissions of SO₂ shall be controlled with the use of clean fuels (i.e. natural gas) control technology. SO₂ emissions to the atmosphere from the Auxiliary Boiler Stack (EP #EX-1) shall not exceed 0.133 lb/hr based on a three-hour block average. *Compliance with this streamlined lb/MMBtu SO₂ emission limit assures compliance with 45CSR §10-3.3.f.*

- a. The auxiliary boiler shall not consume any natural gas with a sulfur content greater than 0.15 grains per 100 cubic feet of natural gas

[45CSR14, R14-0024 §6.1.3.; 45CSR§10-3.3.f.]

6.1.4. PM and PM-10 emissions emitted to the atmosphere from the Auxiliary Boiler Stack (EP #EX-1) shall not exceed 1.26 lb/hr based on a six-hour block average. *Compliance with this streamlined lb/MMBtu PM emission limit assures compliance with 45CSR §2-4.1.b.*

[45CSR14, R14-0024 §6.1.4.; 45CSR§2-4.1.b.]

6.1.5. CO emissions emitted to the atmosphere from the Auxiliary Boiler Stack (EP #EX-1) shall not exceed 9 lb/hr based on a three-hour block average.

[45CSR14, R14-0024 §6.1.5.]

6.1.6. VOC emissions emitted to the atmosphere from the Auxiliary Boiler Stack (EP #EX-1) shall not exceed 1.22 lb/hr based on a three-hour block average.

[45CSR14, R14-0024 §6.1.6.]

6.1.7. The auxiliary boiler stack shall not exhibit visible emission greater than 10% opacity on a 6-minute block averaging period.

[45CSR14, R14-0024 §6.1.7.; 45CSR§2-3.1.]

- 6.1.8. **Operation and Maintenance of Air Pollution Control Equipment.** The permittee shall, to the extent practicable, install, maintain, and operate all pollution control equipment listed in Section 1.0 and associated monitoring equipment in a manner consistent with safety and good air pollution control practices for minimizing emissions, or comply with any more stringent limits set forth in this permit or as set forth by any State rule, Federal regulation, or alternative control plan approved by the Secretary.
[45CSR14, R14-0024 §6.1.8.]

6.2. Monitoring Requirements

- 6.2.1. For each operating day, the permittee shall record the calendar date, amount of fuel consumed, number of hours operated (including the time of start-up and shutdown), and the hourly steam load. Using the amount of fuel consumed, the appropriate Higher Heating Value (HHV) of the fuel and engineering calculations, the permittee shall determine the hourly heat input of the Auxiliary Boiler on a daily basis. A monthly total and 12 month rolling number of hours operated shall be maintained. Such records shall be maintained in accordance with Condition 3.4.1. of this permit.
[45CSR14, R14-0024 §6.2.1.; 45CSR16; 40CFR§60.49b(p); and 45CSR§2A-7.1.a.1.]

6.3. Testing Requirements

- 6.3.1. *[Reserved]*

6.4. Recordkeeping Requirements

- 6.4.1. **Record of Monitoring.** The permittee shall keep records of monitoring information as specified in Condition 3.4.2.
[45CSR14, R14-0024 §6.4.1.]
- 6.4.2. **Record of Maintenance of Air Pollution Control Equipment.** For all pollution control equipment listed in Section 1.0, the permittee shall maintain accurate records of all required pollution control equipment inspection and/or preventative maintenance procedures.
[45CSR14, R14-0024 §6.4.2.]
- 6.4.3. **Record of Malfunctions of Air Pollution Control Equipment.** For all air pollution control equipment listed in Section 1.0, the permittee shall maintain records of the occurrence and duration of any malfunction or operational shutdown of the air pollution control equipment during which excess emissions occur. For each such case, the following information shall be recorded:
- a. The equipment involved.
 - b. Steps taken to minimize emissions during the event.
 - c. The duration of the event.
 - d. The estimated increase in emissions during the event.

For each such case associated with an equipment malfunction, the additional information shall also be recorded:

- e. The cause of the malfunction.
- f. Steps taken to correct the malfunction.
- g. Any changes or modifications to equipment or procedures that would help prevent future recurrences of the malfunction.

[45CSR14, R14-0024 §6.4.3.]

- 6.4.4. The permittee shall maintain records of all maintenance performed on the auxiliary boiler in accordance with 3.4.1. of this permit.

[45CSR14, R14-0024 §6.4.4.]

- 6.4.5. The owner or operator of an affected facility (i.e., auxiliary boiler) who elects to demonstrate that the affected facility combusts only natural gas, that is known to contain an insignificant amount of sulfur in § 60.42b(k) shall obtain and maintain at the affected facility fuel receipts (such as a current, valid purchase contract, tariff sheet, or transportation contract) from the fuel supplier that certify that the gaseous fuel meets the definition of natural gas as defined in § 60.41b and the applicable sulfur limit.

[45CSR16; 40CFR§60.49b(r)(1)]

6.5. Reporting Requirements

- 6.5.1. The permittee shall report the results of any test conducted as required in Section 6.3. of this permit to the Director within 60 days after completing such testing.

[45CSR14, R14-0024 §6.5.1.]

- 6.5.2. The permittee shall submit to the Director on or before March 15 an annual compliance report of the previous calendar year ending on December 31. Such report shall include the following:

- a. Annual capacity factor over the previous calendar year;
- b. The result of any NO_x emission tests required during the reporting period; and
- c. Hours of operation for the previous calendar year.

[45CSR14, R14-0024 §6.5.2.; 45CSR16; 40 CFR §60.49b(q)]

6.6. Compliance Plan

- 6.6.1. NA

7.0 Limestone and Ash Handling Systems [emission point ID(s): *EL-1 –6, 9-11, 12a, 12b, 13a, 13b, EA-1a, 1b, 2a 2b, 3, 4, 6-10, 11a, 11b, 11c, 12*

7.1. Limitations and Standards

7.1.1. The following conditions and requirements are specific to the limestone handling operations:

- a. The material (limestone) transferred through the facility shall not exceed the maximum material throughputs as shown in Table 7.1.1 - “Limestone Handling Transfer Limits” of this permit.
- b. Pollution control mechanisms/measures shall be installed and maintained on all material transfer points in accordance with Table 7.1.1 - “Limestone Handling Transfer Limits” of this permit.

Table 7.1.1 - “Limestone Handling Transfer Limits”				
Transfer Point		Pollution Control Device	Maximum Throughput	
ID	Description		Tons/Hour	Tons/Year
L-1	Truck Dump to Limestone Hopper Feeder	Partial Enclosure with dust suppression	150	275,000
L-2	Feeder Transfer to Bucket Elevator	Full Enclosure w/dust suppression	150	275,000
L-3	Bucket Elevator Discharge to Pile Tripper Belt	Full Enclosure w/dust suppression	150	275,000
L-4	Belt Transfer to Limestone Pile	Partial Enclosure and Telescopic Chute	150	275,000
L-6	Reclaim Transfer to Reclaim Hopper/Belt	Partial Enclosure	150	275,000
L-9	Bucket Elevator Discharge to Conveyor	Partial Enclosure w/dust suppression	150	275,000
L-10	Conveyor to Storage Conveyor	Partial Enclosure w/dust suppression	150	275,000
L-12a	Silo Drop to Weigh Feeder	Full Enclosure	82	275,000
L-12b	Silo Drop to Weigh Feeder	Full Enclosure		
L-13a	Ball Mill	Partial Enclosure	82	275,000
L-13b	Ball Mill	Partial Enclosure		

- c. Stockpile L-5 [SL-5] shall be limited to a maximum storage capacity of 13,680 tons of limestone.
- d. Stockpile L-5 [SL-5] shall be located in a structure with a roof, three full walls and one partial wall.
- e. Fugitive emissions from opening (except for vents as defined in 40CFR§60.671) of the limestone storage structure and the building enclosing the ball mill shall not exhibit opacity greater than 7%.
[40CFR§60.672(e)(1)]

- f. Any transfer point or any source of fugitive emissions that handles or processes limestone that is not located inside a fully enclosed structure shall not exhibit visible emissions greater than 10% opacity on a 6 minute average. This limitation does not apply to visible emissions generated from truck dump (ID L-1).

[40CFR§§60.672(b) and (d)]

- g. The limestone day silo (SL-11) shall be enclosed and vented to a dust collector (EL-11).
 - 1. PM from emission point EL-11 shall not exceed 0.69 lb/hr based on a three-hour block averaging period and 0.86 TPY.
 - 2. PM₁₀ from emission point EL-11 shall not exceed 0.58 lb/hr based on a three-hour block averaging period and 0.73 TPY.
 - 3. Visible emissions from emission point EL-11 shall not exceed 7% opacity on a six-minute block averaging period.

[40CFR §60.672(f)]

[45CSR14, R14-0024 §7.1.1.; 45CSR16; 40 CFR §60.672]

- 7.1.2. The following conditions and requirements are specific to the ash handling operations:

- a. The permittee shall use a negative pressure (vacuum) system to transfer all fly ash. Such system shall include up to three exhausters (SA-11a, SA-11b, SA-11c) that discharge to the atmosphere through emission points EA-11a, EA-11b, and EA-11c. Emissions from these exhausters shall not exceed the following limits:
 - 1. PM emissions from each shall not exceed 0.65 pounds per hour and combined total from all three emission points shall not exceed 5.72 TPY.
 - 2. PM₁₀ emissions from each shall not exceed 0.31 pounds per hour and combined total from all three emission points shall not exceed 2.74 TPY.
 - 3. The permittee shall only operate two of the three exhausters at any given time.
- b. The permittee shall install, operate, and maintain bin exhaust filters to control PM emissions from the fly ash storage silos (CA-1).
- c. The bottom ash storage pile SA-7 shall be limited to a maximum storage capacity of 1,170 tons of bottom ash.
- d. The gypsum storage pile SG-1 shall be limited to a maximum storage capacity of 13,680 tons of gypsum.

[45CSR14, R14-0024 §7.1.2.]

- 7.1.3. *[Reserved]*

- 7.1.4. **Operation and Maintenance of Air Pollution Control Equipment.** The permittee shall, to the extent practicable, install, maintain, and operate all pollution control equipment listed in Section 1.0 and associated monitoring equipment in a manner consistent with safety and good air pollution control practices for minimizing emissions, or comply with any more stringent limits set forth in this permit or as set forth by any State rule, Federal regulation, or alternative control plan approved by the Secretary.
[45CSR14, R14-0024 §7.1.4.]

7.2. Monitoring Requirements

- 7.2.1. The permittee shall conduct visible emission checks in accordance with Condition 3.2.1. of this permit for the purpose of determining ongoing compliance with the visible emission standards (7.1.1.e. and 7.1.1.f.) from the limestone structures, limestone silo, and any other transfer point not located within a structure. Refer to Table B in Appendix B of this permit for a list of sources.
[45CSR14, R14-0024 §7.2.1.]

7.3. Testing Requirements

- 7.3.1. [Reserved]

7.4. Recordkeeping Requirements

- 7.4.1. **Record of Monitoring.** The permittee shall keep records of monitoring information as specified in Condition 3.4.2.
[45CSR14, R14-0024 §7.4.1.]
- 7.4.2. **Record of Maintenance of Air Pollution Control Equipment.** For all pollution control equipment listed in Section 1.0, the permittee shall maintain accurate records of all required pollution control equipment inspection and/or preventative maintenance procedures.
[45CSR14, R14-0024 §7.4.2.]
- 7.4.3. **Record of Malfunctions of Air Pollution Control Equipment.** For all air pollution control equipment listed in Section 1.0, the permittee shall maintain records of the occurrence and duration of any malfunction or operational shutdown of the air pollution control equipment during which excess emissions occur. For each such case, the following information shall be recorded:
- a. The equipment involved.
 - b. Steps taken to minimize emissions during the event.
 - c. The duration of the event.
 - d. The estimated increase in emissions during the event.
- For each such case associated with an equipment malfunction, the additional information shall also be recorded:
- e. The cause of the malfunction.
 - f. Steps taken to correct the malfunction.

- g. Any changes or modifications to equipment or procedures that would help prevent future recurrences of the malfunction.

[45CSR14, R14-0024 §7.4.3.]

- 7.4.4. The permittee shall record the amount of limestone received, and bottom and fly ash shipped from the facility on a monthly basis. Such records shall be maintained in accordance with Condition 3.4.1. of this permit.

[45CSR14, R14-0024 §7.4.4.]

7.5. Reporting Requirements

- 7.5.1. *[Reserved]*

7.6. Compliance Plan

- 7.6.1. NA

8.0 Internal Combustion Engines [emission point ID(s): *EG-1, EP-1*]

8.1. Limitations and Standards

8.1.1. The following conditions and requirements are specific to the internal combustion engines powering the emergency generator (ID #SG-1) and fire pump (ID #SP-1):

- a. The hours of operation for the engines of the emergency generator and fire pump shall be limited to 500 hours per rolling 12 month time period for each engine.
- b. The sulfur content of the fuel used in the emergency generator and fire pump engines shall not exceed 0.05% sulfur by weight.
- c. The emergency generator engine (ID #SG-1) shall not consume more than 14,750 gallons of fuel on an annual basis.
- d. The fire pump engine (ID #SP-1) shall not consume more than 7,380 gallons of fuel on an annual basis.
- e. Emissions from the emergency generator and fire pump engines shall not exceed the following limits:

Pollutants	Emergency Generator		Fire Pump	
	lb/hr	tons per year	lb/hr	tons per year
SO ₂	6.5	1.6	3.3	0.825
PM ₁₀	1.13	0.28	0.56	0.14
CO	8.85	2.21	4.43	1.11
NO _x	20.9	5.23	10.5	2.6
VOC	1.21	0.30	0.64	0.16

- f. The permittee shall perform annual maintenance of the emergency generator and fire pump engine and shall keep records of this maintenance.

[45CSR14, R14-0024 §7.1.3.]

8.1.2. The internal combustion engines powering the emergency generator (ID #SG-1) and fire pump (ID #SP-1) must meet the requirements of 40 CFR 63 Subpart ZZZZ by meeting the requirements of 40 CFR part 60 Subpart IIII, for compression ignition engines. No further requirements apply for such engines under 40 CFR 63 Subpart ZZZZ.

[45CSR34, 40 CFR §63.6590(c)(1)]

40 CFR 60 Subpart IIII Requirements

8.1.3. The emergency generator engine (SG-1) must comply with the emission standards in 40 CFR §60.4202(a)(2) for all pollutants (i.e., the certification emission standards for new nonroad CI engines in 40 CFR §89.112 and 40 CFR §89.113)

[45CSR16; 40 CFR §60.4205(b)]

- 8.1.4. The fire pump engine (SP-1) must comply with the following emission standards in Table 4 of 40 CFR 60 Subpart IIII as follows:

Pollutants	g/KW-hr (g/HP-hr)
NMHC + NO _x	10.5 (7.8)
PM	0.54 (0.40)
CO	3.5 (2.6)

[45CSR16; 40 CFR §60.4205(c); 40 CFR 60 Subpart IIII, Table 4]

- 8.1.5. The emergency generator and fire pump engines must meet the emission standards of 40 CFR §60.4205 over the entire life of the engines.

[45CSR16; 40 CFR §60.4206]

- 8.1.6. The diesel fuel used in the emergency generator and fire pump engines must meet the requirements of 40 CFR §80.510(b) for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to October 1, 2010, may be used until depleted.

[45CSR16; 40 CFR §60.4207(b)]

- 8.1.7. The compliance requirements for the emergency generator and fire pump engines below must be followed:

- a. The engines must be operated and maintained according to the manufacturer's emission-related written instructions;
- b. Change only those emission-related settings that are permitted by the manufacturer; and
- c. Meet the requirements of 40 CFR Parts 89 and/or 1068 as they apply to the engines

[45CSR16; 40 CFR §60.4211(a)]

- 8.1.8. The following requirements are taken verbatim (including paragraph numbering) from 40 CFR 60 Subpart IIII, §60.4211(f) and are applicable to the emergency generator and fire pump engines:

- (f) If you own or operate an emergency stationary ICE, you must operate the emergency stationary ICE according to the requirements in paragraphs (f)(1) through (3) of this section. In order for the engine to be considered an emergency stationary ICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in nonemergency situations for 50 hours per year, as described in paragraphs (f)(1) through (3) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (3) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

- (1) There is no time limit on the use of emergency stationary ICE in emergency situations.

- (2) You may operate your emergency stationary ICE for any combination of the purposes specified in paragraphs (f)(2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph (f)(3) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).
- (i) Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.
 - (ii) Emergency stationary ICE may be operated for emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy Emergencies (incorporated by reference, see § 60.17), or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.
 - (iii) Emergency stationary ICE may be operated for periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.
- (3) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. Except as provided in paragraph (f)(3)(i) of this section, the 50 hours per calendar year for nonemergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.
- (i) The 50 hours per year for nonemergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:
 - (A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator;
 - (B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.
 - (C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.
 - (D) The power is provided only to the facility itself or to support the local transmission and distribution system.

- (E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

[45CSR16; 40 CFR §60.4211(f)]

8.2. Monitoring Requirements

8.2.1. NA

8.3. Testing Requirements

8.3.1. NA

8.4. Recordkeeping Requirements

- 8.4.1. The permittee shall keep monthly records of hours of operation and a 12-month rolling total for each engine. If the engine is equipped with a non-resettable hour meter, the permittee shall only be required to record the number of hours of operation at the end of the calendar year. Such records shall be maintained in accordance with Condition 3.4.1 of this permit.

[45CSR14, R14-0024 §7.4.5.]

8.5. Reporting Requirements

8.5.1. NA

8.6. Compliance Plan

8.6.1. NA

APPENDIX A

(CAIR Permit Application)



CAIR Permit Application

Page 1

For sources subject to the Clean Air Interstate Rule Trading Programs under 45CSR39, 45CSR40 and 45CSR41, the West Virginia Department of Environmental Protection, Division of Air Quality has prepared this CAIR Permit Application. Please refer to sections 21 and 22 of 45CSR39, 45CSR40 and 45CSR41, as applicable.

This submission is: ☒ New ☐ Revised

STEP 1
Identify the source
by plant name, and
ORIS or facility code

<i>Longview Power</i>	<i>061 - 00134</i>	<i>56671</i>
Plant Name	West Virginia ID Number	ORIS/Facility Code

STEP 2
Enter the unit ID# for
each CAIR unit and
indicate to which
CAIR programs each
unit is subject (by
placing an "X" in the
column)

Unit ID#	NO _x Annual	NO _x Ozone Season	SO ₂ Annual
<i>001</i>	<i>X</i>	<i>X</i>	<i>X</i>

STEP 3
Read the standard
requirements and
the certification,
enter the name of the
CAIR designated
representative, and
sign and date

Standard Requirements

(a) Permit Requirements.

(1) The CAIR designated representative of each CAIR NO_x Annual source, CAIR NO_x Ozone Season source and CAIR SO₂ source (as applicable) required to have a Title V operating permit and each CAIR NO_x Annual unit, CAIR NO_x Ozone Season unit and CAIR SO₂ unit (as applicable) required to have a Title V operating permit at the source shall:

(i) Submit to the Secretary a complete CAIR permit application under 45CSR§39-22, 45CSR§40-22 and 45CSR§41-22 (as applicable) in accordance with the deadlines specified in 45CSR§39-21, 45CSR§40-21 and 45CSR§41-21 (as applicable); and

(ii) Submit in a timely manner any supplemental information that the Secretary determines is necessary in order to review a CAIR permit application and issue or deny a CAIR permit.

(2) The owners and operators of each CAIR NO_x Annual source, CAIR NO_x Ozone Season source and CAIR SO₂ source (as applicable) required to have a Title V operating permit and each CAIR NO_x Annual unit, CAIR NO_x Ozone Season unit and CAIR SO₂ unit (as applicable) required to have a Title V operating permit at the source shall have a CAIR permit issued by the Secretary under sections 20 through 24 of 45CSR39, 45CSR40 and 45CSR41 (as applicable) for the source and operate the source and the unit in compliance with such CAIR permit.

(3) Except as provided in sections 80 through 88 of 45CSR39, 45CSR40 and 45CSR41, the owners and operators of a CAIR NO_x Annual source, CAIR NO_x Ozone Season source and CAIR SO₂ source (as applicable) that is not otherwise required to have a Title V operating permit and each CAIR NO_x Annual unit, CAIR NO_x Ozone Season unit and CAIR SO₂ unit (as applicable) that is not otherwise required to have a Title V operating permit are not required to submit a CAIR permit application and to have a CAIR permit, under sections 20 through 24 of 45CSR39, 45CSR40 and 45CSR41 (as applicable) for such CAIR NO_x Annual source, CAIR NO_x Ozone Season source and CAIR SO₂ source (as applicable) and such CAIR NO_x Annual unit, CAIR NO_x Ozone Season unit and CAIR SO₂ unit (as applicable).

STEP 3,
continued

(b) Monitoring, reporting and recordkeeping requirements.

(1) The owners and operators and the CAIR designated representative, of each CAIR NO_x Annual source, CAIR NO_x Ozone Season source and CAIR SO₂ source (as applicable) and each CAIR NO_x Annual unit, CAIR NO_x Ozone Season unit and CAIR SO₂ unit (as applicable) at the source shall comply with the monitoring, reporting and recordkeeping requirements of sections 70 through 75 of 45CSR39, 45CSR40 and 45CSR41 (as applicable).

(2) The emissions measurements recorded and reported in accordance with sections 70 through 75 of 45CSR39, 45CSR40 and 45CSR41 (as applicable) shall be used to determine compliance by each CAIR NO_x Annual source, CAIR NO_x Ozone Season source and CAIR SO₂ source (as applicable) with the CAIR NO_x Annual emissions limitation, CAIR NO_x Ozone Season emissions limitation and CAIR SO₂ emissions limitation (as applicable) under 45CSR§39-6.3, 45CSR§40-6.3 and 45CSR§41-6.3 (as applicable).

(c) Nitrogen oxides annual emissions requirements.

(1) As of the allowance transfer deadline for the 2009 control period and each control period thereafter, the owners and operators of each CAIR NO_x Annual source and each CAIR NO_x Annual unit at the source shall hold, in the source's compliance account, CAIR NO_x Annual allowances available for compliance deductions for the control period under 45CSR§39-54.1 in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO_x Annual units at the source, as determined in accordance with sections 70 through 75 of 45CSR39.

(2) A CAIR NO_x Annual unit shall be subject to the requirements under 45CSR§39-6.3.a for the control period starting on the later of January 1, 2009 or the deadline for meeting the unit's monitor certification requirements under subdivisions 70.2.a, 70.2.b, or 70.2.e of 45CSR39, and for each control period thereafter.

(3) A CAIR NO_x Annual allowance shall not be deducted, for compliance with the requirements under 45CSR§39-6.3.a, for the control period in a calendar year before the year for which the CAIR NO_x Annual allowance was allocated.

(4) CAIR NO_x Annual allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Allowance Tracking System accounts in accordance with sections 50 through 62, and 80 through 88 of 45CSR39.

(5) A CAIR NO_x Annual allowance is a limited authorization to emit one ton of nitrogen oxides in accordance with the CAIR NO_x Annual Trading Program. No provision of the CAIR NO_x Annual Trading Program, the CAIR permit application, the CAIR permit, or an exemption under 45CSR§39-5 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.

(6) A CAIR NO_x Annual allowance does not constitute a property right.

(7) Upon recordation by the Administrator under sections 40 through 62, and 80 through 88 of 45CSR39, every allocation, transfer, or deduction of a CAIR NO_x Annual allowance to or from a CAIR NO_x Annual source's compliance account is incorporated automatically in any CAIR permit of the source.

(d) Nitrogen oxides ozone season emissions requirements.

(1) As of the allowance transfer deadline for the 2009 ozone season and each ozone season thereafter, the owners and operators of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO_x Ozone Season allowances available for compliance deductions for the ozone season under 45CSR§40-54.1 in an amount not less than the tons of total nitrogen oxides emissions for the ozone season from all CAIR NO_x Ozone Season units at the source, as determined in accordance with sections 70 through 75 of 45CSR40.

(2) A CAIR NO_x Ozone Season unit shall be subject to the requirements under 45CSR§40-6.3.a for the ozone season starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under subdivisions 70.2.a, 70.2.b, 70.2.c or 70.2.g of 45CSR40 and for each ozone season thereafter.

(3) A CAIR NO_x Ozone Season allowance shall not be deducted, for compliance with the requirements under 45CSR§40-6.3.a, for an ozone season in a calendar year before the year for which the CAIR NO_x Ozone Season allowance was allocated.

(4) CAIR NO_x Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Ozone Season Allowance Tracking System accounts in accordance with sections 50 through 62, and 80 through 88 of 45CSR40.

(5) A CAIR NO_x Ozone Season allowance is a limited authorization to emit one ton of nitrogen oxides in accordance with the CAIR NO_x Ozone Season Trading Program. No provision of the CAIR NO_x Ozone Season Trading Program, the CAIR permit application, the CAIR permit, or an exemption under 45CSR§40-5 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.

(6) A CAIR NO_x Ozone Season allowance does not constitute a property right.

(7) Upon recordation by the Administrator under subdivision 43.3, sections 51 through 57, 60 through 62, and 80 through 88 of 45CSR40, every allocation, transfer, or deduction of a CAIR NO_x Ozone Season allowance to or from a CAIR NO_x Ozone Season source's compliance account is incorporated automatically in any CAIR permit of the source.

(e) Sulfur dioxide annual emission requirements.

(1) As of the allowance transfer deadline for the 2010 control period and each control period thereafter, the owners and operators of each CAIR SO₂ source and each CAIR SO₂ unit at the source shall hold, in the source's compliance account, a tonnage equivalent of CAIR SO₂ allowances available for compliance deductions for the control period, as determined in accordance with subsections 54.1 and 54.2 of 45CSR§41 in an amount not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO₂ units at the source, as determined in accordance with sections 70 through 75 of 45CSR41.

(2) A CAIR SO₂ unit shall be subject to the requirements under 45CSR§41-6.3.a for the control period starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under subdivisions 70.2.a, 70.2.b, or 70.2.e of 45CSR41 and for each control period thereafter.

(3) A CAIR SO₂ allowance shall not be deducted, for compliance with the requirements under 45CSR§41-6.3.a, for a control period in a calendar year before the year for which the CAIR SO₂ allowance was allocated.

(4) CAIR SO₂ allowances shall be held in, deducted from, or transferred into or among CAIR SO₂ Allowance Tracking System accounts in accordance with sections 51 through 62, and 80 through 88 of 45CSR41.

(5) A CAIR SO₂ allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO₂ Trading Program. No provision of the CAIR SO₂ Trading Program, the CAIR permit application, the CAIR permit, or an exemption under 45CSR§41-5 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.

(6) A CAIR SO₂ allowance does not constitute a property right.

(7) Upon recordation by the Administrator under sections 51 through 57, 60 through 62, and 80 through 88 of 45CSR41, every allocation, transfer, or deduction of a CAIR SO₂ allowance to or from a CAIR SO₂ source's compliance account is incorporated automatically in any CAIR permit of the source.

STEP 3,
continued

(f) Excess emissions requirements.

(1) If a CAIR NO_x Annual source emits nitrogen oxides during any control period in excess of the CAIR NO_x Annual emissions limitation, then:

(i) The owners and operators of the source and each CAIR NO_x Annual unit at the source shall surrender the CAIR NO_x Annual allowances required for deduction under 45CSR§39-54.4.a and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or West Virginia Code §22-5-1 et seq; and

(ii) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 45CSR39, the Clean Air Act, and West Virginia Code §22-5-1 et seq.

(2) If a CAIR NO_x Ozone Season source emits nitrogen oxides during any ozone season in excess of the CAIR NO_x Ozone Season emissions limitation, then:

(i) The owners and operators of the source and each CAIR NO_x Ozone Season unit at the source shall surrender the CAIR NO_x Ozone Season allowances required for deduction under 45CSR§40-54.4.a and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or West Virginia Code §22-5-1 et seq; and

(ii) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 45CSR40, the Clean Air Act, and West Virginia Code §22-5-1 et seq.

(3) If a CAIR SO₂ source emits sulfur dioxide during any control period in excess of the CAIR SO₂ emissions limitation, then:

(i) The owners and operators of the source and each CAIR SO₂ unit at the source shall surrender the CAIR SO₂ allowances required for deduction under 45CSR§41-54.4.a and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or West Virginia Code §22-5-1 et seq; and

(ii) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 45CSR41, the Clean Air Act, and West Virginia Code §22-5-1 et seq.

(g) Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of a CAIR NO_x Annual source, CAIR NO_x Ozone Season source and CAIR SO₂ source (as applicable) and each CAIR NO_x Annual unit, CAIR NO_x Ozone Season unit and CAIR SO₂ unit (as applicable) at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Secretary or the Administrator.

(i) The certificate of representation under 45CSR§39-13, 45CSR§40-13 and 45CSR§41-13 (as applicable) for the CAIR designated representative for the source and each CAIR NO_x Annual unit, CAIR NO_x Ozone Season unit and CAIR SO₂ unit (as applicable) at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 45CSR§39-13, 45CSR§40-13 and 45CSR§41-13 (as applicable) changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with sections 70 through 75 of 45CSR39, 45CSR40 and 45CSR41 (as applicable), provided that to the extent that sections 70 through 75 of 45CSR39, 45CSR40 and 45CSR41 (as applicable) provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Annual Trading Program, CAIR NO_x Ozone Season Trading Program and CAIR SO₂ Trading Program (as applicable).

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO_x Annual Trading Program, CAIR NO_x Ozone Season Trading Program and CAIR SO₂ Trading Program (as applicable) or to demonstrate compliance with the requirements of the CAIR NO_x Annual Trading Program, CAIR NO_x Ozone Season Trading Program and CAIR SO₂ Trading Program (as applicable).

(2) The CAIR designated representative of a CAIR NO_x Annual source, CAIR NO_x Ozone Season source and CAIR SO₂ source (as applicable) and each CAIR NO_x Annual unit, CAIR NO_x Ozone Season unit and CAIR SO₂ unit (as applicable) at the source shall submit the reports required under the CAIR NO_x Annual Trading Program, CAIR NO_x Ozone Season Trading Program and CAIR SO₂ Trading Program (as applicable) including those under sections 70 through 75 of 45CSR39, 45CSR40 and 45CSR41 (as applicable).

(h) Liability.

(1) Each CAIR NO_x Annual source, CAIR NO_x Ozone Season source and CAIR SO₂ source (as applicable) and each NO_x unit, CAIR NO_x Ozone Season unit and CAIR SO₂ unit (as applicable) shall meet the requirements of the CAIR NO_x Annual Trading Program, CAIR NO_x Ozone Season Trading Program and CAIR SO₂ Trading Program (as applicable).

(2) Any provision of the CAIR NO_x Annual Trading Program, CAIR NO_x Ozone Season Trading Program or CAIR SO₂ Trading Program (as applicable) that applies to a CAIR NO_x Annual source, CAIR NO_x Ozone Season source or CAIR SO₂ source (as applicable) or the CAIR designated representative of a CAIR NO_x Annual source, CAIR NO_x Ozone Season source or CAIR SO₂ source (as applicable) shall also apply to the owners and operators of such source and of the CAIR NO_x Annual units, CAIR NO_x Ozone Season units or CAIR SO₂ units (as applicable) at the source.

(3) Any provision of the CAIR NO_x Annual Trading Program, CAIR NO_x Ozone Season Trading Program or CAIR SO₂ Trading Program (as applicable) that applies to a CAIR NO_x Annual unit, CAIR SO₂ unit or CAIR NO_x Ozone Season unit (as applicable) or the CAIR designated representative of a CAIR NO_x Annual unit, CAIR NO_x Ozone Season unit or CAIR SO₂ unit (as applicable) shall also apply to the owners and operators of such unit.

(i) Effect on Other Authorities.


No provision of the CAIR NO_x Annual Trading Program, CAIR NO_x Ozone Season Trading Program and CAIR SO₂ Trading Program (as applicable), a CAIR permit application, a CAIR permit, or an exemption under 45CSR§39-5, 45CSR§40-5, or 45CSR§41-5 (as applicable) shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_x Annual source, CAIR NO_x Ozone Season source and CAIR SO₂ source (as applicable) or CAIR NO_x Annual unit, CAIR NO_x Ozone Season unit and CAIR SO₂ unit (as applicable) from compliance with any other provision of the applicable, approved State implementation plan, a federally enforceable permit, or the Clean Air Act.

<i>Longview Power</i> Plant Name

STEP 3,
continued

Certification

I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

<i>Charles Huguenard</i> CAIR Designated Representative	
Signature 	Date <i>1/16/09</i>

APPENDIX B

(Appendix B from R14-0024)

APPENDIX B

Table A- Coal Handling Emission Points Subject to a Visible Emission Standard			
Emission Point Id	Equipment Description	Emission Unit/Source located in structure	Limit (% Opacity)
SC-3	Discharge of Receiving Belt to Stacking Belt	Transfer House (L-TH-1)	20
SC-6	Discharge of Receiving Belt to Transfer Belt		
SC-4	Discharge of Stacking Belt to Stockpile	None	20
SC-7	Discharge of Reclaim Conveyor to Surge Bin	Crusher House (L-CH)	20
SC-13	Feeder to Crusher B		
SC-14	Feeder to Crusher A		
SC-15	Discharge from Crusher B		
SC-16	Discharge from Crusher A	Tripper Transfer (L-TH2)	20
SC-18	Discharge from Plant Feed Belt B		
SC-19	Discharge from Plant Feed Belt A		
SC-21A (EC-21)	Discharge from Tripper Belt A	Boiler Building (Emission Point EC-21)	20
SC-21B (EC-21)	Discharge from Tripper Belt B		

Table B- Limestone Handling Emission Points Subject to a Visible Emission Standard			
Emission Point Id	Equipment Description	Structure Source located in	Limit (% Opacity)
SL-2	Discharge from the Truck Feeder Conveyor	Limestone Building (A-frame)	10
SL-3	Discharge from the Limestone Bucket Elevator to Bypass Conveyor		
SL-9	Discharge from the Limestone Bucket Elevator to Tripper Conveyor		
SL-6	Reclaim Hopper		
SL-10	Discharge from the Bypass Conveyor	Day Silo (Emission Point EL-11)	7
SL-11	Discharge from Day Silo Feed Conveyor to Day Silo		
SL-12a	Discharge from Day Silo to Feeder A	Ball Mill Building	10
SL-12b	Discharge from Day Silo to Feeder A		
SL-13a	Discharge from Feeder A to Mill A		
SL-13b	Discharge from Feeder B to Mill B		